



AN ENVIRONMENTAL COMPLIANCE COMPANY

316 W. Indiana Ave.
Chesterton, IN 46304

EZY CHEK SYSTEMS

PRODUCT LINE TEST

DATE AND TIME

8/22/23 - 6:35-8:15

Test Location Information

PC # and WO #	
Name and FID #	Citgo - FID 1634
Address	1356 Portage Ave.
City/State/Zip	South Bend, IN 46628
Contact	
Phone	

Testing Company Information

Name	Midwest Tank Testing
Address	316 W. Indiana Ave.
City/State/Zip	Chesterton, IN 46304
Phone	800-975-1436

Technician Information

Name	Chris Zell
Email	support@midwesttanktesting.com
Applied Pressure	1-1/2 Times Working Pressure, Min 50 PSI

PRODUCT LINE TEST - DATA (LT)

#1	Product Type:		Regular		
TIME	DATA	-/+	GPL	RES	GPH
7:00	90	0	0.0037	0.0000	0.0000
7:15	90	0	0.0037	0.0000	0.0000
7:30	90	0	0.0037	0.0000	0.0000
7:45	90	0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:			Pass		

#2	Product Type:		Premium		
TIME	DATA	-/+	GPL	RES	GPH
7:00	90	0	0.0037	0.0000	0.0000
7:15	90	0	0.0037	0.0000	0.0000
7:30	90	0	0.0037	0.0000	0.0000
7:45	90	0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:			Pass		

#3	Product Type:		Diesel		
TIME	DATA	-/+	GPL	RES	GPH
7:00	78	0	0.0037	0.0000	0.0000
7:15	78	0	0.0037	0.0000	0.0000
7:30	78	0	0.0037	0.0000	0.0000
7:45	78	0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:			Pass		

#4	Product Type:				
TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:					

#5	Product Type:				
TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:					

#6	Product Type:				
TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:					

COMMENTS/RECOMMENDATIONS: Regular and Premium functioning element screws need repaired. The lines under disp 3/4 are mislabeled.



INDIANA HOMELAND SECURITY

Underground Storage Tank



CHRIS ZELL
316 W INDIANA AVE
CHESTERTON, INDIANA

STATE/PERMIT #
UC111987

ISSUE
12/29/2022

EFFECTIVE
12/30/2022

EXPIRATION
12/29/2024

DISCIPLINES

☒ Installation or Retrofitting

☐ Decommissioning Closure

☐ Cathodic Protection

☐ Decommissioning Removal

☐ Testing

The attached testing was completed at this site by an IDHS certified technician.

Technician's Signature: _____

Chris Zell


Midwest Tank Testing
AN ENVIRONMENTAL COMPLIANCE COMPANY

316 W. Indiana Ave.
Chesterton, IN 46304
(800) 975-1436
Serving the Midwest Since 1990