

HN Food Plus
1356 Portage Ave.
South Bend, IN 46616
574-855-1368
01/22/2024 14:58:19

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

Unleaded
Unleaded
Capacity: 10,039.0

Begin End
01/17/2024 01/21/2024
01:08:13 06:46:28
Result Pass
Slope 0.00
Status 0
Volume Qualify(%) 14

Premium
Premium
Capacity: 10,039.0

Begin End
01/10/2024 01/10/2024
09:16:17 11:24:59
Result Pass
Slope -0.03
Status 0
Volume Qualify(%) 14

Diesel
Diesel
Capacity: 8,271.0

Begin End
01/22/2024 01/22/2024
13:14:53 14:41:56
Result Pass
Slope 0.04
Status 0
Volume Qualify(%) 14

HN Food Plus
1356 Portage Ave.
South Bend, IN 46616
574-855-1368
01/22/2024 14:58:59

TANK TEST REPORT
Last Available

units:gal, in, °F

No Records Found

HN Food Plus
1356 Portage Ave.
South Bend, IN 46616
574-855-1368
01/22/2024 14:59:20

REGULATORY REPORT
(Passed Tests)
Last 2 Months

units:gph

TANKS (MONTHLY)

Tank 1
Unleaded
SCALD
Slope 0.00
▶ 01/17/2024 01:08:13
⊙ 01/21/2024 06:46:28
Slope -0.02
▶ 12/29/2023 01:49:39
⊙ 12/29/2023 03:16:21
Slope 0.01
▶ 12/01/2023 01:59:48
⊙ 12/01/2023 03:26:30
Slope 0.08
▶ 11/03/2023 01:53:53
⊙ 11/03/2023 05:29:07

Tank 2
Premium
SCALD
Slope -0.03
▶ 01/10/2024 09:16:17
⊙ 01/10/2024 11:24:59
Slope -0.05
▶ 12/28/2023 00:18:48
⊙ 12/28/2023 01:44:49
Slope 0.03
▶ 11/28/2023 00:33:34
⊙ 11/28/2023 01:59:23
Slope 0.08
▶ 11/07/2023 05:00:47
⊙ 11/07/2023 06:46:10

Tank 3
Diesel
SCALD
Slope 0.04
▶ 01/22/2024 13:14:53
⊙ 01/22/2024 14:41:56
Slope 0.00
▶ 01/09/2024 08:20:01
⊙ 01/10/2024 00:47:51