

HN Food Plus
1356 Portage Ave.
South Bend, IN 46616
574-855-1368
05/04/2024 14:15:01

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

Unleaded
Unleaded
Capacity: 10,039.0
Begin End
05/04/2024 05/04/2024
05:22:07 08:15:09
Result Pass
Slope 0.03
Status 0
Volume Qualify(%) 14

Premium
Premium
Capacity: 10,039.0
Begin End
05/01/2024 05/01/2024
02:57:02 05:07:38
Result Pass
Slope 0.01
Status 0
Volume Qualify(%) 14

Diesel
Diesel
Capacity: 8,271.0
Begin End
04/04/2024 04/05/2024
23:40:32 01:16:53
Result Pass
Slope 0.02
Status 0
Volume Qualify(%) 14

.....

HN Food Plus
1356 Portage Ave.
South Bend, IN 46616
574-855-1368
05/04/2024 14:15:06

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

Unleaded
Unleaded
Capacity: 10,039.0
Begin End
05/04/2024 05/04/2024
05:22:07 08:15:09
Result Pass
Slope 0.03
Status 0
Volume Qualify(%) 14

Premium
Premium
Capacity: 10,039.0
Begin End
05/01/2024 05/01/2024
02:57:02 05:07:38
Result Pass
Slope 0.01
Status 0
Volume Qualify(%) 14

Diesel
Diesel
Capacity: 8,271.0
Begin End
04/04/2024 04/05/2024
23:40:32 01:16:53
Result Pass
Slope 0.02
Status 0
Volume Qualify(%) 14

HN Food Plus
1356 Portage Ave.
South Bend, IN 46616
574-855-1368
05/04/2024 14:15:42

TANK TEST REPORT
Last Available

units:gal, in, °F

No Records Found

HN Food Plus
1356 Portage Ave.
South Bend, IN 46616
574-855-1368
05/04/2024 14:15:52

ALARMS REPORT
Last 30 Days

Unleaded
High product volume
Alarm
! 04/19/2024 12:26:54
✓ 04/19/2024 16:39:53

Unleaded
High product volume
Alarm
! 04/11/2024 10:04:01
✓ 04/11/2024 17:17:05
.....

HN Food Plus
1356 Portage Ave.
South Bend, IN 46616
574-855-1368
05/04/2024 14:16:08

REGULATORY REPORT
(Passed Tests)
May 2024

units:gph

TANKS (MONTHLY)

Tank 1
Unleaded
SCALD
Slope 0.03
▶ 05/04/2024 05:22:07
⊗ 05/04/2024 08:15:09

Tank 2
Premium
SCALD
Slope 0.01
▶ 05/01/2024 02:57:02
⊗ 05/01/2024 05:07:38