

1356 Portage Ave.
South Bend, IN 46616
574-855-1368
04/10/2024 16:56:33

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

Unleaded
Unleaded
Capacity: 10,039.0

Begin End
04/10/2024 04/10/2024
03:17:50 04:44:43
Result Pass
Slope -0.01
Status 0
Volume Qualify(%) 14

Premium
Premium
Capacity: 10,039.0

Begin End
03/26/2024 03/26/2024
03:44:08 05:11:09
Result Pass
Slope -0.01
Status 0
Volume Qualify(%) 14

Diesel
Diesel
Capacity: 8,271.0

Begin End
04/04/2024 04/05/2024
23:40:32 01:16:53
Result Pass
Slope 0.02
Status 0
Volume Qualify(%) 14

.....

HN Food Plus
1356 Portage Ave.
South Bend, IN 46616
574-855-1368
04/10/2024 16:56:33

REGULATORY REPORT
(Passed Tests)
April 2024

units:gph

TANKS (MONTHLY)

Tank 1
Unleaded
SCALD
Slope -0.01
▶ 04/10/2024 03:17:50
⊗ 04/10/2024 04:44:43

Tank 3
Diesel
SCALD
Slope 0.02
▶ 04/04/2024 23:40:32
⊗ 04/05/2024 01:16:53