
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 1634	Contact Number
Facility Name CITTNO	Contact email
Address 1356 Borage Ave, South Bend, IN 46616	Date of Inspection 01/13/25
Operator on Duty Name	Name of the Person Conducting Inspection AKSHIT

	Operator Training	Registration/Notification Form	Release Detection	Operator Notified	Operator Notified	Operator Notified	Operator Notified
Operator Training current	☐ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ No
Is Registration current with correct owner, operator etc.	☐ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ No
Release Detection Method	☒ ATG	☐ CIM	☐ SIR	☐ IC	☐ Other		
Make and Model	VT-57 SS50EUD						
Does it have paper?	☒ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ No
Is it in Alarm mode?	☒ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ No
Necessary Monthly Printout Taken	☒ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ No
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ No
Under Dispenser Containments (UDC)	☒ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name _____ Signature _____ Date _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com