

TANKNOLOGY

CATHODIC PROTECTION RECTIFIER MAINTENANCE SHEET

Customer/Location: 1356 Postage Ave

Location of Rectifier Unit: STOCK ROOM

Type of Rectifier Unit: TCP

Type of Anodes: CONT. E2-SS Type of Ground Bed: _____

No. of Anodes: 7 Size: $\varnothing$ X Long 5/8

Ground Bed Location: _____

Rectifier Mfg. By: _____ Model: _____ SN# _____

Rectifier AC Input: _____ Volts, _____ Amperes, _____ Phase, _____ Hz

Rectifier DC Output: 8.0 Volts, 8 Amperes, Shunt: mv = A.

Installed: 5/21/98

Comments: Fiberglass lined steel tank

[illegible]

60-Day Inspection Results for Impressed Current Cathodic Protection Systems

FACILITY NAME 136 1356 PORTAGE AVE HW FOOD PLUS
 AMP RANGE RECOMMENDED 8.0
 VOLTAGE RANGE RECOMMENDED 8

Date	Your Name	Voltage Reading	Amp Reading	Is Your System Running Properly? (Yes/No)
10/12/04	GARRY	20.58	2.57	Y
10/13/04	G	20.60	2.60	Y
10/14/04	G	20.62	2.62	Y
10/15/04	G	20.64	2.64	Y
10/16/04	G	20.66	2.66	Y
10/17/04	G	20.68	2.68	Y
10/18/04	G	20.70	2.70	Y
10/19/04	G	20.71	2.73	X
10/20/04	G	20.73	2.76	Y
10/21/04	G	20.76	2.79	Y
10/22/04	GARRY	20.78	2.81	Y
10/23/04	GARRY	20.81	2.84	X
10/24/04	G	20.83	2.86	X
10/25/04	G	20.86	2.90	Y
10/26/04	G	20.90	2.93	Y
10/27/04	G	20.93	2.96	Y
10/28/04	G	20.95	2.97	Y
10/29/04	G	20.97	2.99	Y

- If the rectifier voltage and/or amperage output(s) are outside the recommended operating levels, contact a cathodic protection expert to address the problem.
- Never turn off your rectifier.
- KEEP THIS RECORD FOR AT LEAST 6 MONTHS AFTER THE DATE OF THE LAST READING

60-Day Inspection Results for Impressed Current Cathodic Protection Systems

FACILITY NAME: _____

AMP RANGE RECOMMENDED: _____

VOLTAGE RANGE RECOMMENDED: _____

Date	Your Name	Voltage Reading	Amp Reading	Is Your System Running Properly? (Yes/No)
10/30/34	GARRY	20.98	2.01	Y
10/31/4	/	20.99	2.05	Y
11/1/4	/	20.701	2.09	Y
11/2/4	/	20.61	2.011	Y
11/3/4	/	20.31	2.013	Y
11/4/4	/	20.41	2.17	Y
11/5/4	/	20.61	2.21	Y
11/6/4	/	20.71	2.23	Y
11/7/4	GARRY	20.741	2.26	Y
11/8/4	/	20.311	2.31	Y
11/9/4	/	20.301	2.36	Y
11/10/4	GARRY	20.411	2.41	Y
11/11/4	G	20.461	2.46	Y
11/12/4	G	20.511	2.51	Y
11/13/4	G	20.561	2.56	Y
11/14/4	G	20.611	2.61	Y
11/15/4	G	20.711	2.66	Y
11/16/4	G	20.811	2.71	Y

- If the rectifier voltage and/or amperage output(s) are outside the recommended operating levels, contact a cathodic protection expert to address the problem.
- Never turn off your rectifier.
- KEEP THIS RECORD FOR AT LEAST 6 MONTHS AFTER THE DATE OF THE LAST READING

60-Day Inspection Results for Impressed Current Cathodic Protection Systems

FACILITY NAME: INDY FOOD MART

AMP RANGE RECOMMENDED: _____

VOLTAGE RANGE RECOMMENDED: _____

Date	Your Name	Voltage Reading	Amp Reading	Is Your System Running Properly? (Yes/No)
11/17/4	GARRY	20.83	2.73	Y
11/18/4	GARRY	20.85	2.74	Y
11/19/4	GARRY	20.86	2.75	Y
11/20/4	/	20.88	2.77	Y
11/21/4	/	20.89	2.79	Y
11/22/4	/	20.90	2.80	Y
11/23/4	/	20.91	2.82	X
11/24/4	/	20.92	2.83	/
11/25/4	/	20.93	2.6	/
11/26/4	/	20.94	2.88	/
11/27/4	GARRY	20.95	2.90	/
11/28/4	/	20.96	2.91	/
11/29/4	/	20.97	2.92	/
11/30/4	/	20.98	2.94	Y
12/1/4	/	20.99	2.95	Y
12/2/4	GARRY	21.01	2.96	Y
12/3/4	/	21.02	2.97	Y
12/4/4	/	21.03	2.98	/

- If the rectifier voltage and/or amperage output(s) are outside the recommended operating levels, contact a cathodic protection expert to address the problem.
- Never turn off your rectifier.
- KEEP THIS RECORD FOR AT LEAST 6 MONTHS AFTER THE DATE OF THE LAST READING

60-Day Inspection Results for Impressed Current Cathodic Protection Systems

FACILITY NAME: EITCO - INDY FOOD MART

AMP RANGE RECOMMENDED: _____

VOLTAGE RANGE RECOMMENDED: _____

Date	Your Name	Voltage Reading	Amp Reading	Is Your System Running Properly? (Yes/No)
12/5/4	GARRY	20.01	0.01	
12/6/4	GARRY	20.02	0.1	
12/7/4	/	20.04	0.1	
12/8/4	/	20.06	0.2	
12/9/4	/	20.08	0.2	
12/10/4	/	20.11	0.2	
12/11/4	/	20.13	0.2	
12/12/4	/	20.15	0.2	
12/13/4	GARRY	20.17	0.2	
12/14/4	GARRY	20.19	0.2	
12/15/4	/	20.20	0.3	
12/16/4	/	20.21	0.3	
12/17/4	/	20.22	0.3	
12/18/4	/	20.23	0.4	
12/19/4	/	20.26	0.5	
12/20/4	GARRY	20.27	0.6	
12/21/4	GARRY	20.28	0.6	
12/22/4		20.30	0.7	

- If the rectifier voltage and/or amperage output(s) are outside the recommended operating levels, contact a cathodic protection expert to address the problem.
- Never turn off your rectifier.
- KEEP THIS RECORD FOR AT LEAST 6 MONTHS AFTER THE DATE OF THE LAST READING

60-Day Inspection Results for Impressed Current Cathodic Protection Systems

FACILITY NAME: CITYO - INDY FOOD MART

AMP RANGE RECOMMENDED: _____

VOLTAGE RANGE RECOMMENDED: _____

Date	Your Name	Voltage Reading	Amp Reading	Is Your System Running Properly? (Yes/No)
12/23/4	GARRY	20.01	0.1	Y
12/24/4	GARRY	20.02	0.1	Y
12/25/4	GARRY	20.03	0.1	Y
12/26/4	/	20.4	0.1	Y
12/27/4	/	20.5	0.1	Y
12/28/4	/	20.6	0.1	Y
12/29/4	/	20.7	0.2	/
12/30/4	/	20.8	0.2	
12/31/4	/	20.9	0.2	
1/1/5	/	20.10	0.2	
1/2/5	GARRY	20.11	0.2	/
1/3/5	GARRY	20.12	0.3	
1/4/5	/	20.13	0.3	
1/5/5	/	20.14	0.3	
1/6/5	/	20.15	0.3	Y
1/7/5	/	20.16	0.3	Y
1/8	GARRY	20.17		

2025
Jan-

- If the rectifier voltage and/or amperage output(s) are outside the recommended operating levels, contact a cathodic protection expert to address the problem.
- Never turn off your rectifier.
- KEEP THIS RECORD FOR AT LEAST 6 MONTHS AFTER THE DATE OF THE LAST READING

60-Day Inspection Results for Impressed Current Cathodic Protection Systems

FACILITY NAME: GTQ-MAX FOOD

AMP RANGE RECOMMENDED: _____

VOLTAGE RANGE RECOMMENDED: _____

Date	Your Name	Voltage Reading	Amp Reading	Is Your System Running Properly? (Yes/No)
1/8/25	GARRY	20.19	0.4	Y
1/9/25	GARRY	20.21	0.4	Y
1/10/25		20.22	0.4	Y
1/11/25		20.24	0.4	Y
1/12/25		20.26	0.5	Y
1/13/25		20.27	0.5	Y
1/14/25		20.28	0.6	Y
1/15/25		20.29	0.7	
1/16/25		20.30	0.8	
1/17/25		20.31	0.8	
1/18/25		20.34	0.9	
1/19/25		20.35	0.10	
1/20/25		20.37	0.10	
1/21/25	GARRY	20.40	0.10	
1/22/25		20.42	0.11	Y
1/23/25	GARRY	20.44	0.12	Y
1/24/25		20.46	0.13	

- If the rectifier voltage and/or amperage output(s) are outside the recommended operating levels, contact a cathodic protection expert to address the problem.
- Never turn off your rectifier.
- KEEP THIS RECORD FOR AT LEAST 6 MONTHS AFTER THE DATE OF THE LAST READING