

30 DAYS WALK THROUGH INSPECTION

Tanks Data

UST Facility I.D. (FID) #	1634	Contact Number	
Facility Name	0190	Contact email	
Address	1356 Heritage Ave South End	Date of Inspection	04-17-25
Operator on Duty Name	IN-46616	Name of the Person Conducting Inspection	Molon Singh

Operator Training current	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is Registration current with correct owner, operator etc.	Registration/Notification Form ☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Release Detection Method	Release Detection ☒ ATG ☐ CIM ☐ SIR ☐ IC ☐ Other		
Make and Model	FFS-15-550		
Does it have paper?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is it in Alarm mode?	☐ Yes ☒ No	Operator Notified	☐ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Necessary Monthly Printout Taken	☐ Yes ☒ No	Operator Notified	☐ Yes ☐ No
Spill Buckets			
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	Fill Ports ☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Are Sumps Clean and free from water, debris, product etc?	Piping/STP Sumps ☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Are UDCs clean and free from water, debris, product etc?	Under Dispenser Containments (UDC) ☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

317-645-0215

tanksdata@gmail.com

www.tanksdata.com

Signature

Date