

PETROLEUM TESTING SERVICES, LLC
PO BOX 146
YORKTOWN, IN 47396
765-749-5540
EMAIL:petroleumtesting@aol.com

SITE NAME: MARATHON
STREET NAME: 1701 W JEFFERSON
CITY,STATE,ZIP: PLYMOUTH, IN 46563
DATE: 1/4/2023 TIME: 9:00A

LINE AND LEAK DETECTOR TEST

PRODUCT	UNL	PREM	DSL	UNL2	5
OPERATING SYSTEM	PR	PR	PR	PR	
STP MODEL	RJ	RJ	RJ	RJ	
OPERATING PRESSURE	30	30	30	30	
TEST PRESSURE	50	50	50	50	
ISOLATION	BV	BV	BV	BV	
LINE MATERIAL	FLEX	FLEX	FLEX	FLEX	
BEGINNING LEVEL	0.0900	0.0875	0.0440	0.0900	
10 MIN	0.0900	0.0875	0.0440	0.0900	
20 MIN	0.0900	0.0875	0.0440	0.0900	
30 MIN	0.0900	0.0875	0.0440	0.0900	
AMOUNT OF CHANGE	0.0000	0.0000	0.0000	0.0000	
RESULT	PASS	PASS	PASS	PASS	
LEAK DETECTOR MODEL	RJ	VMI	VMI	FE	
LEAK DETECTOR MAKE	FX1V	LD2000	LD2000	MLD	
OPENING TIME	2	2	2	2	
PAUSE PRESSURE	10	20	20	16	
HOLDING PRESSURE	15	15	12	15	
TYPE OF TEST	3GAL/HR	3GAL/HR	3GAL/HR	3GAL/HR	
RESULT	PASS	PASS	PASS	PASS	

COMMENTS

TECHNICIAN JOHN LANNOM CERTIFICATION UC20129333