

06/06/23 11:13 AM

Hoke's
1701 W Jefferson st
Plymouth, IN 46563
J11203417608002

Sensor Status Report -
All Sensors

NO DATA AVAILABLE

06/06/23 11:14 AM

Hoke's
1701 W Jefferson st
Plymouth, IN 46563
J11203417608002

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 1: RUL N

REPORT TYPE = LAST GROSS
DATE/TIME = 06/06/23 3:37
METHOD = SLD Gross Test
AVG. VOLUME = 15561
% VOLUME = 98.4

REPORT TYPE = LAST PERIODIC
DATE/TIME = 06/06/23 4:17
METHOD = CSLD Periodic Test
HOURS = 118
AVG. VOLUME = 14720
% VOLUME = 93.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/06/23 4:17
METHOD = CSLD Periodic Test
HOURS = 118
AVG. VOLUME = 14720
% VOLUME = 93.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/31/23 4:06
METHOD = CSLD Periodic Test
HOURS = 88
AVG. VOLUME = 14434
% VOLUME = 91.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/29/23 6:52
METHOD = CSLD Periodic Test
HOURS = 52
AVG. VOLUME = 5406
% VOLUME = 34.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/13/23 0:17
METHOD = CSLD Periodic Test
HOURS = 41
AVG. VOLUME = 5221
% VOLUME = 33.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/15/23 1:25
METHOD = CSLD Periodic Test
HOURS = 44
AVG. VOLUME = 6869
% VOLUME = 43.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/29/23 6:26
METHOD = CSLD Periodic Test
HOURS = 38
AVG. VOLUME = 5285
% VOLUME = 33.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/05/22 0:21
METHOD = CSLD Periodic Test
HOURS = 37
AVG. VOLUME = 5505
% VOLUME = 34.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/30/22 4:21
METHOD = CSLD Periodic Test
HOURS = 44