

PETROLEUM TESTING SERVICES, LLC
PO BOX 146
YORKTOWN, IN 47396
765-749-5540
EMAIL:petroleumtesting@aol.com

SITE: MARATHON FID 2808
ADDRESS: 1701 W JEFFERSON
CITY,ST,ZIP: PLYMOUTH, IN 45563 DATE: 1/4/2023

ATG FUNCTIONALITY

ATG MAKE AND MODEL

TANK NUMBER

PRODUCT

TANK VOLUME

TANK DIAMETER

TANK PROBE HAS NO DAMAGED PARTS?

DAMAGED OR MISSING PARTS REPLACED?

FLOATS MOVE FREELY ON STEM?

FUEL FLOAT AGREES W/ CONSOLE?

INCH LEVEL WATER FLOAT ACTIVATES ALARM?

WATER FLOAT AGREES W/ CONSOLE?

INCH LEVEL OVERFILL ACTIVATES ALARM?

OVERFILL ALARM AGREES W/ CONSOLE?

ALL SENSORS LABELED CORRECTLY?

STP/UDC SENSORS ACTIVATE ALARM?

INTERSTITIAL TANK SENSORS ACTIVATE ALARM?

.2 MONTHLY MONITORING ACTIVE?

BATTERY BACKUP IS FUNCTIONAL?

RESULT

COMMENTS:

VR 450

1	2	3	4	5
UNL1	UNL2	PREM	DSL	KERO
15818	6423	8272	4187	4000
114	96	96	96	64
N	N	N	N	N
NA	NA	NA	NA	NA
Y	Y	Y	Y	Y
Y	Y	Y	Y	Y
2	2	2	2	2
Y	Y	Y	Y	Y
104	84	84	84	55
Y	Y	Y	Y	Y
NA	NA	NA	NA	NA
NA	NA	NA	NA	NA
NA	NA	NA	NA	NA
Y	Y	Y	Y	Y
YES				
PASS	PASS	PASS	PASS	PASS

TECHNICIAN: JOHN LANNOM

CERTIFICATION:

UC20129333