

02/09/24 1:54 PM

Hoke's
1701 W Jefferson St
Plymouth, IN 46563
J11203417608002

Sensor Status Report -
All Sensors

NO DATA AVAILABLE

02/09/24 1:54 PM

Hoke's
1701 W Jefferson St
Plymouth, IN 46563
J11203417608002

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 1: RUL N

REPORT TYPE = LAST GROSS
DATE/TIME = 02/09/24 3:44
METHOD = SLD Gross Test
AVG. VOLUME = 9086
% VOLUME = 57.4

REPORT TYPE = LAST PERIODIC
DATE/TIME = 02/09/24 3:22
METHOD = CSLD Periodic Test
HOURS = 36
AVG. VOLUME = 10522
% VOLUME = 66.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/06/24 3:30
METHOD = CSLD Periodic Test
HOURS = 42
AVG. VOLUME = 10580
% VOLUME = 66.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/15/24 1:24
METHOD = CSLD Periodic Test
HOURS = 41
AVG. VOLUME = 10192
% VOLUME = 64.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/31/23 6:21
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 10590
% VOLUME = 66.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/05/23 4:28
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 8517
% VOLUME = 53.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/08/23 7:53
METHOD = CSLD Periodic Test
HOURS = 41
AVG. VOLUME = 8669
% VOLUME = 54.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/28/23 4:14
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 7587
% VOLUME = 48.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/18/23 1:36
METHOD = CSLD Periodic Test
HOURS = 47
AVG. VOLUME = 7172
% VOLUME = 45.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/01/23 3:41
METHOD = CSLD Periodic Test
HOURS = 50
AVG. VOLUME = 15564
% VOLUME = 98.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/30/23 4:23
METHOD = CSLD Periodic Test
HOURS = 55
AVG. VOLUME = 15564
% VOLUME = 98.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/31/23 4:06
METHOD = CSLD Periodic Test
HOURS = 88
AVG. VOLUME = 14434
% VOLUME = 91.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/29/23 6:52
METHOD = CSLD Periodic Test
HOURS = 52
AVG. VOLUME = 5406
% VOLUME = 34.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/13/23 0:17
METHOD = CSLD Periodic Test
HOURS = 41
AVG. VOLUME = 5221
% VOLUME = 33.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/15/23 1:25
METHOD = CSLD Periodic Test
HOURS = 44
AVG. VOLUME = 6869
% VOLUME = 43.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/29/23 6:26
METHOD = CSLD Periodic Test
HOURS = 38
AVG. VOLUME = 5285