

000
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 2808	Contact Number
Facility Name M B RATHN	Contact email
Address 1701 W Jefferson St, Plymouth	Date of Inspection 09/03/24
Operator on Duty Name IN 46563	Name of the Person Conducting Inspection AKSHIT

Operator Training current	Operator Training	Registration/Notification Form	Release Detection	Release Detection Method	Male and Model	Does it have paper?	Is it in Alarm mode?	Interstitial Monitoring Sensor Status Normal	Necessary Monthly Printout Taken
☐ Yes	☐ No	☐ Yes	☐ No	☒ M/G	☒ M/G	☒ Yes	☒ No	☒ Yes	☒ No
Is Registration current with correct owner, operator etc.	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified
☐ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No
Release Detection	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified
☒ M/G	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No
Are Spill Buckets Clean and free from water, debris, product etc?	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified
☒ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No
Are the Spill Bucket in good condition and free of damage/cracks	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified
☒ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified
☒ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No
Are Sumps Clean and free from water, debris, product etc?	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified
☒ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No
Are UDCs clean and free from water, debris, product etc?	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified	Operator Notified
☒ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name 317-645-0215 tanksdata@gmail.com tanksdata.com 20220516