

10/04/24 3:36 PM

Doke's
1701 W Jefferson st
Plymouth, IN 46563
J11203417608002

Selected Range:
09/19/24 12:00 AM - 10/04/24 11:59 PM

Sensor Status History Report -
All Sensors

NO DATA AVAILABLE

10/04/24 3:36 PM

Doke's
1701 W Jefferson st
Plymouth, IN 46563
J11203417608002

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 1: RUL N

REPORT TYPE = LAST GROSS
DATE/TIME = 10/04/24 3:49
METHOD = SLD Gross Test
AVG. VOLUME = 5927
% VOLUME = 37.5

REPORT TYPE = LAST PERIODIC
DATE/TIME = 10/04/24 4:38
METHOD = CSLD Periodic Test
HOURS = 31
AVG. VOLUME = 8748
% VOLUME = 55.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/02/24 5:40
METHOD = CSLD Periodic Test
HOURS = 32
AVG. VOLUME = 8894
% VOLUME = 56.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/22/24 6:39
METHOD = CSLD Periodic Test
HOURS = 34
AVG. VOLUME = 9144
% VOLUME = 57.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/14/24 0:42
METHOD = CSLD Periodic Test
HOURS = 42
AVG. VOLUME = 9016
% VOLUME = 57.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/31/24 3:58
METHOD = CSLD Periodic Test
HOURS = 41
AVG. VOLUME = 8467
% VOLUME = 53.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/23/24 9:11
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 11195
% VOLUME = 70.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/01/24 0:43
METHOD = CSLD Periodic Test
HOURS = 114
AVG. VOLUME = 10

10/04/24 3:36 PM

Hoke's
1701 W Jefferson st
Plymouth, IN 46563
J11203417608002

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 2: RUL S

REPORT TYPE = LAST GROSS
DATE/TIME = 10/04/24 3:49
METHOD = SLD Gross Test
AVG. VOLUME = 5978
% VOLUME = 93.1

REPORT TYPE = LAST PERIODIC
DATE/TIME = 10/04/24 4:38
METHOD = CSLD Periodic Test
HOURS = 39
AVG. VOLUME = 5983
% VOLUME = 93.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/01/24 0:50
METHOD = CSLD Periodic Test
HOURS = 44
AVG. VOLUME = 5983
% VOLUME = 93.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/01/24 4:42
METHOD = CSLD Periodic Test
HOURS = 51
AVG. VOLUME = 5993
% VOLUME = 93.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/01/24 21:54
METHOD = CSLD Periodic Test
HOURS = 27
AVG. VOLUME = 6011
% VOLUME = 93.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/05/24 20:57
METHOD = CSLD Periodic Test
HOURS = 38
AVG. VOLUME = 6028
% VOLUME = 93.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/01/24 1:30
METHOD = CSLD Periodic Test
HOURS = 38
AVG. VOLUME = 6069
% VOLUME = 94.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/23/24 4:11
METHOD = CSLD Periodic Test
HOURS = 25

10/04/24 3:36 PM

Hoke's
1701 W Jefferson st
Plymouth, IN 46563
J11203417608002

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 3: PRM

REPORT TYPE = LAST PERIODIC
DATE/TIME = 10/04/24 15:27
METHOD = CSLD Periodic Test
HOURS = 49
AVG. VOLUME = 1872
% VOLUME = 22.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/04/24 15:27
METHOD = CSLD Periodic Test
HOURS = 49
AVG. VOLUME = 1872
% VOLUME = 22.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/01/24 1:41
METHOD = CSLD Periodic Test
HOURS = 38
AVG. VOLUME = 1856
% VOLUME = 22.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/01/24 3:22
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 2148
% VOLUME = 26.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/25/24 16:01
METHOD = CSLD Periodic Test
HOURS = 32
AVG. VOLUME = 2613
% VOLUME = 31.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/30/24 22:12
METHOD = CSLD Periodic Test
HOURS = 36
AVG. VOLUME = 2013
% VOLUME = 24.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/01/24 0:43
METHOD = CSLD Periodic Test
HOURS = 62
AVG. VOLUME = 2500
% VOLUME = 30.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/04/24 15:29
METHOD = CSLD Periodic Test
HOURS = 61
AVG. VOLUME = 2504
% VOLUME = 30.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/31/24 21:20
METHOD = CSLD Periodic Test
HOURS = 111
AVG. VOLUME = 2347

10/04/24 3:36 PM

Mike's
101 W Jefferson st
Bloomington, IN 46563
1203417608002

ANK LEAK TEST HISTORY -
TESTED TEST RESULTS

4: DSL

REPORT TYPE = LAST PERIODIC
DATE/TIME = 10/04/24 15:13
METHOD = CSLD Periodic Test
DURS = 33
VG. VOLUME = 2036
VOLUME = 48.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/04/24 15:13
METHOD = CSLD Periodic Test
DURS = 33
VG. VOLUME = 2036
VOLUME = 48.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/04/24 11:47
METHOD = CSLD Periodic Test
DURS = 47
VG. VOLUME = 2215
VOLUME = 52.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/08/24 4:25
METHOD = CSLD Periodic Test
DURS = 36
VG. VOLUME = 2346
VOLUME = 56.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/14/24 13:16
METHOD = CSLD Periodic Test
DURS = 36
VG. VOLUME = 2508
VOLUME = 59.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/07/24 6:38
METHOD = CSLD Periodic Test
DURS = 47
VG. VOLUME = 2542
VOLUME = 60.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/14/24 12:35
METHOD = CSLD Periodic Test
DURS = 44
VG. VOLUME = 2144
VOLUME = 51.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/26/24 13:30
METHOD = CSLD Periodic Test
DURS = 68
VG. VOLUME = 1534
VOLUME = 36.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/06/24 16:46
METHOD = CSLD Periodic Test
DURS = 37
VG. VOLUME = 2596
VOLUME = 62.0

0/04/24 3:38 PM

oke's
701 W Jefferson st
lymouth, IN 46563
11203417608002

ANK LEAK TEST HISTORY -
ASSED TEST RESULTS

5: KERO

REPORT TYPE = LAST PERIODIC
DATE/TIME = 10/04/24 14:35
METHOD = CSLD Periodic Test
DOURS = 118
VG. VOLUME = 1941
VOLUME = 48.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/04/24 14:35
METHOD = CSLD Periodic Test
DOURS = 118
VG. VOLUME = 1941
VOLUME = 48.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/30/24 23:51
METHOD = CSLD Periodic Test
DOURS = 86
VG. VOLUME = 1654
VOLUME = 41.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/07/24 8:00
METHOD = CSLD Periodic Test
DOURS = 82
VG. VOLUME = 454
VOLUME = 11.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/01/24 1:37
METHOD = CSLD Periodic Test
DOURS = 68
VG. VOLUME = 509
VOLUME = 12.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/01/24 0:56
METHOD = CSLD Periodic Test
DOURS = 56
VG. VOLUME = 656
VOLUME = 16.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/01/24 11:48
METHOD = CSLD Periodic Test
DOURS = 43
VG. VOLUME = 1206
VOLUME = 30.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/01/23 14:05
METHOD = CSLD Periodic Test
DOURS = 62
VG. VOLUME = 1466
VOLUME = 36.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/01/23 1:45
METHOD = CSLD Periodic Test