

8/03/24 6:09 PM

oke's
701 W Jefferson st
lymouth, IN 46563
11203417608002

ensor Status Report -
ll Sensors

DATA AVAILABLE

8/03/24 6:10 PM

oke's
701 W Jefferson st
lymouth, IN 46563
11203417608002

ANK LEAK TEST HISTORY -
PASSED TEST RESULTS

1: RUL N

REPORT TYPE = LAST GROSS
DATE/TIME = 08/03/24 7:56
METHOD = SLD Gross Test
AVG. VOLUME = 6864
VOLUME = 43.4

REPORT TYPE = LAST PERIODIC
DATE/TIME = 08/03/24 6:06
METHOD = CSLD Periodic Test
HOURS = 47
AVG. VOLUME = 8458
VOLUME = 53.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/02/24 4:16
METHOD = CSLD Periodic Test
HOURS = 40
AVG. VOLUME = 8559
VOLUME = 54.1

08/03/24 6:11 PM

Hoke's
1701 W Jefferson st
Plymouth, IN 46563
J11203417608002

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

2: RUL S

REPORT TYPE = LAST GROSS
DATE/TIME = 08/03/24 7:56
METHOD = SLD Gross Test
VG. VOLUME = 5999
VOLUME = 93.4

REPORT TYPE = LAST PERIODIC
DATE/TIME = 08/03/24 6:06
METHOD = CSLD Periodic Test
OURS = 37
VG. VOLUME = 6008
VOLUME = 93.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/01/24 21:54
METHOD = CSLD Periodic Test
OURS = 27
VG. VOLUME = 6011
VOLUME = 93.6

08/03/24 6:15 PM

Hoke's
1701 W Jefferson st
Plymouth, IN 46563
J11203417608002

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 4: DSL

REPORT TYPE = LAST PERIODIC
DATE/TIME = 08/03/24 17:40
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 1637
% VOLUME = 39.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/01/24 9:51
METHOD = CSLD Periodic Test
HOURS = 32
AVG. VOLUME = 1927
% VOLUME = 46.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/14/24 13:16
METHOD = CSLD Periodic Test

08/03/24 6:14 PM

Hoke's
1701 W Jefferson st
Plymouth, IN 46563
J11203417608002

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 3: PRM

REPORT TYPE = LAST PERIODIC
DATE/TIME = 08/03/24 13:38
METHOD = CSLD Periodic Test
HOURS = 38
AVG. VOLUME = 2005
% VOLUME = 24.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/01/24 3:22
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 2148
% VOLUME = 26.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/25/24 16:01
METHOD = CSLD Periodic Test
HOURS = 32
AVG. VOLUME = 2613
% VOLUME = 31.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/30/24 22:12
METHOD = CSLD Periodic Test

08/03/24 6:17 PM

Hoke's
1701 W Jefferson st
Plymouth, IN 46563
J11203417608002

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 5: KERO

REPORT TYPE = LAST PERIODIC
DATE/TIME = 04/13/24 8:00
METHOD = CSLD Periodic Test
HOURS = 19
AVG. VOLUME = 451
% VOLUME = 11.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/07/24 8:00
METHOD = CSLD Periodic Test
HOURS = 82
AVG. VOLUME = 454
% VOLUME = 11.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/01/24 1:37
METHOD = CSLD Periodic Test
HOURS = 68
AVG. VOLUME = 509
% VOLUME = 12.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/01/24 0:56
METHOD = CSLD Periodic Test
HOURS = 56
AVG. VOLUME = 656
% VOLUME = 16.4