

30 DAYS WALK THROUGH INSPECTION

001

Tanks Data

UST Facility I.D. (FID) # 2808 Contact Number

Facility Name MARKATHON Contact email

Address 1701 W Jefferson St, Plymouth, MI 48150 Date of Inspection 06/10/24

Operator on Duty Name Name of the Person Conducting Inspection AKSHIT SHARMA

Operator Training current

Operator Training ☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Is Registration current with correct owner, operator etc. Registration/Notification Form ☐ Yes ☐ No Operator Notified ☐ Yes ☐ No

Release Detection Method

Release Detection ☒ ATG ☐ DIM ☐ BIR ☐ TC ☐ Other

Make and Model

VPRTLS 450

Does it have paper?

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Is it in Alarm mode?

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Interstitial Monitoring Sensor Status Normal

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Necessary Monthly Printout Taken

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Spill Buckets

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Are Spill Buckets Clean and free from water, debris, product etc?

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Fill Ports

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Are Sumps Clean and free from water, debris, product etc?

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Under Dispenser Containments (UDC)

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Are UDCs clean and free from water, debris, product etc?

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com

20220516