

2/16/24 5:05 PM

oke's
701 W Jefferson st
lymouth, IN 46563
11203417608002

ANK LEAK TEST HISTORY -
PASSED TEST RESULTS

4: DSL

REPORT TYPE = LAST PERIODIC
DATE/TIME = 12/16/24 15:47
METHOD = CSLD Periodic Test
DOURS = 51
VG. VOLUME = 2252
VOLUME = 53.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/13/24 8:08
METHOD = CSLD Periodic Test
DOURS = 45
VG. VOLUME = 2555
VOLUME = 61.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/27/24 20:06
METHOD = CSLD Periodic Test
DOURS = 44
VG. VOLUME = 2425
VOLUME = 57.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/09/24 21:00
METHOD = CSLD Periodic Test
DOURS = 33
VG. VOLUME = 2300
VOLUME = 54.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/04/24 11:47
METHOD = CSLD Periodic Test
DOURS = 47
VG. VOLUME = 2215
VOLUME = 52.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/08/24 4:25
METHOD = CSLD Periodic Test
DOURS = 36
VG. VOLUME = 2346
VOLUME = 56.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/14/24 13:16
METHOD = CSLD Periodic Test
DOURS = 36
VG. VOLUME = 2508
VOLUME = 59.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/07/24 6:38
METHOD = CSLD Periodic Test
DOURS = 47
VG. VOLUME = 2542
VOLUME = 60.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/14/24 12:35
METHOD = CSLD Periodic Test
DOURS = 44
VG. VOLUME = 2144
VOLUME = 51.2

REPORT TYPE = FULLEST PERIODIC

12/16/24 5:05 PM

Hoke's
1701 W Jefferson st
Plymouth, IN 46563
J11203417608002

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 1: RUL N

REPORT TYPE = LAST GROSS
DATE/TIME = 12/16/24 3:31
METHOD = SLD Gross Test
AVG. VOLUME = 9961
% VOLUME = 63.0

REPORT TYPE = LAST PERIODIC
DATE/TIME = 12/16/24 4:07
METHOD = CSLD Periodic Test
HOURS = 37
AVG. VOLUME = 9971
% VOLUME = 63.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/16/24 4:07
METHOD = CSLD Periodic Test
HOURS = 37
AVG. VOLUME = 9971
% VOLUME = 63.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/04/24 0:23
METHOD = CSLD Periodic Test
HOURS = 36
AVG. VOLUME = 9505
% VOLUME = 60.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/27/24 9:01
METHOD = CSLD Periodic Test
HOURS = 34
AVG. VOLUME = 9788
% VOLUME = 61.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/22/24 6:39
METHOD = CSLD Periodic Test
HOURS = 34
AVG. VOLUME = 9144
% VOLUME = 57.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/14/24 0:42
METHOD = CSLD Periodic Test
HOURS = 42
AVG. VOLUME = 9016
% VOLUME = 57.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/31/24 3:58
METHOD = CSLD Periodic Test
HOURS = 41

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/31/23 4:06
METHOD = CSLD Periodic Test
HOURS = 88
AVG. VOLUME = 14434

12/16/24 5:05 PM

Hoke's
1701 W Jefferson st
Plymouth, IN 46563
J11203417608002

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 2: RUL S

REPORT TYPE = LAST GROSS
DATE/TIME = 12/16/24 3:31
METHOD = SLD Gross Test
AVG. VOLUME = 5073
% VOLUME = 79.0

REPORT TYPE = LAST PERIODIC
DATE/TIME = 12/16/24 4:07
METHOD = CSLD Periodic Test
HOURS = 128
AVG. VOLUME = 5934
% VOLUME = 92.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/02/24 22:15
METHOD = CSLD Periodic Test
HOURS = 50
AVG. VOLUME = 5950
% VOLUME = 92.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/01/24 0:37
METHOD = CSLD Periodic Test
HOURS = 47
AVG. VOLUME = 5968
% VOLUME = 92.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/01/24 0:50
METHOD = CSLD Periodic Test
HOURS = 44
AVG. VOLUME = 5983
% VOLUME = 93.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/01/24 4:42
METHOD = CSLD Periodic Test
HOURS = 51
AVG. VOLUME = 5993
% VOLUME = 93.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/01/24 21:54
METHOD = CSLD Periodic Test
HOURS = 27
AVG. VOLUME = 6011
% VOLUME = 93.6

REPORT TYPE = FULLEST PERIODIC

12/16/24 5:06 PM

Hoke's
1701 W Jefferson st
Plymouth, IN 46563
J11203417608002

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 3: PRM

REPORT TYPE = LAST PERIODIC
DATE/TIME = 12/16/24 14:04
METHOD = CSLD Periodic Test
HOURS = 37
AVG. VOLUME = 2130
% VOLUME = 25.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/02/24 11:12
METHOD = CSLD Periodic Test
HOURS = 37
AVG. VOLUME = 2579
% VOLUME = 31.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/30/24 19:42
METHOD = CSLD Periodic Test
HOURS = 34
AVG. VOLUME = 2567
% VOLUME = 31.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/08/24 9:38
METHOD = CSLD Periodic Test
HOURS = 37
AVG. VOLUME = 2147
% VOLUME = 26.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/01/24 1:41
METHOD = CSLD Periodic Test
HOURS = 38
AVG. VOLUME = 1856
% VOLUME = 22.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/01/24 3:22
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 2148
% VOLUME = 26.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/25/24 16:01
METHOD = CSLD Periodic Test
HOURS = 32
AVG. VOLUME = 2613
% VOLUME = 31.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/30/24 22:12
METHOD = CSLD Periodic Test
HOURS = 36
AVG. VOLUME = 2013
% VOLUME = 24.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/01/24 0:43
METHOD = CSLD Periodic Test

12/16/24 5:06 PM

Hoke's
1701 W Jefferson st
Plymouth, IN 46563
J11203417608002

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 5: KERO

REPORT TYPE = LAST PERIODIC
DATE/TIME = 12/16/24 14:16
METHOD = CSLD Periodic Test
HOURS = 53
AVG. VOLUME = 1687
% VOLUME = 42.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/01/24 12:01
METHOD = CSLD Periodic Test
HOURS = 65
AVG. VOLUME = 2051
% VOLUME = 51.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/01/24 2:53
METHOD = CSLD Periodic Test
HOURS = 89
AVG. VOLUME = 2256
% VOLUME = 56.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/08/24 10:32
METHOD = CSLD Periodic Test
HOURS = 120
AVG. VOLUME = 2301
% VOLUME = 57.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/30/24 23:51
METHOD = CSLD Periodic Test
HOURS = 86
AVG. VOLUME = 1654
% VOLUME = 41.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/07/24 8:00
METHOD = CSLD Periodic Test
HOURS = 82
AVG. VOLUME = 454
% VOLUME = 11.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/01/24 1:37
METHOD = CSLD Periodic Test
HOURS = 68
AVG. VOLUME = 509
% VOLUME = 12.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/01/24 0:56