



UST TESTING/INSPECTION RESULTS SUMMARY

OWNER NAME: Tanks Data
OWNER ADDRESS: 0
OWNER CITY/STATE/ZIP: 0

TESTING DATE: 8/28/2023

LOCATION NAME: Brothers Stop N Go
LOCATION ADDRESS: 1701 W Jefferson
LOCATION CITY/STATE: Plymouth, IN 46563
LOCATION FID#: 02808

THREE YEAR TESTS/INSPECTIONS

SPILL BUCKET INTERGRITY TESTING

COMPLETED

TANK NO	PRODUCT	CONSTRUCTION	RESULT
1	RUL 1	Single-Walled	PASS
2	RUL 2	Single-Walled	FAIL
3	PUL	Single-Walled	FAIL
4	DSL	Single-Walled	PASS
5	KER	Single-Walled	PASS

HYDROSTATIC SUMP TEST

NOT PERFORMED

SUMP ID	MATERIAL	DEPTH	HYDROSTATIC RESULT	VISUAL RESULT

OVERFILL EQUIPMENT INSPECTION

NOT PERFORMED

TANK	PRODUCT	TYPE	BALL FLOAT RESULT	AUTO SHUT OFF RESULT

OVERFILL ALARM TEST

COMPLETED

TANK	PRODUCT	BRAND/MODEL	RESULT
1	RUL 1	V/R TLS 450	FAIL
2	RUL 2	V/R TLS 450	FAIL
3	PUL	V/R TLS 450	FAIL
4	DSL	V/R TLS 450	FAIL
5	KER	V/R TLS 450	FAIL

LEGEND:

RUL	Regular Unleaded
DSL	Diesel
PUL	Premium Unleaded
KER	Kerosene
ODSL	Off Road Diesel
REC	Recreational

SITE PHOTOS

TEST DATE: 8/28/2023
LOCATION NAME: Brothers Stop N Go
LOCATION ADDRESS: 1701 W Jefferson
LOCATION CITY/STATE: Plymouth, IN 46563
LOCATION PHONE: 0
LOCATION CONTACT: Virendar Kumar

OWNER NAME: Tanks Data
OWNER ADDRESS: 0
OWNER CITY/STATE/ZIP: 0
LOCATION FID#: 02808
WORK ORDER NO: NE-0559

RUL1 OVERFILL EQUIP TEST



KER OVERFILL EQUIP TEST



DSL OVERFILL EQUIP TEST



PUL OVERFILL EQUIP TEST





SITE PHOTOS

TEST DATE: 8/28/2023
LOCATION NAME: Brothers Stop N Go
LOCATION ADDRESS: 1701 W Jefferson
LOCATION CITY/STATE: Plymouth, IN 46563
LOCATION PHONE: 0
LOCATION CONTACT: Virendar Kumar

OWNER NAME: Tanks Data
OWNER ADDRESS: 0
OWNER CITY/STATE/ZIP: 0
LOCATION FID#: 02808
WORK ORDER NO: NE-0559

RUL2 OVERFILL EQUIP TEST



INTENTIONALLY LEFT BLANK

RUL1 SPILL BUCKET TEST START 6.5"



RUL1 SPILL BUCKET TEST END 6.5"



SITE PHOTOS

TEST DATE: 8/28/2023
LOCATION NAME: Brothers Stop N Go
LOCATION ADDRESS: 1701 W Jefferson
LOCATION CITY/STATE: Plymouth, IN 46563
LOCATION PHONE: 0
LOCATION CONTACT: Virendar Kumar

OWNER NAME: Tanks Data
OWNER ADDRESS: 0
OWNER CITY/STATE/ZIP: 0
LOCATION FID#: 02808
WORK ORDER NO: NE-0559

RUL2 SPILL BUCKET TEST START 15"



RUL2 SPILL BUCKET TEST END 14.5"



PUL SPILL BUCKET TEST START 7.5"



PUL SPILL BUCKET TEST END 6"



SITE PHOTOS

TEST DATE: 8/28/2023
LOCATION NAME: Brothers Stop N Go
LOCATION ADDRESS: 1701 W Jefferson
LOCATION CITY/STATE: Plymouth, IN 46563
LOCATION PHONE: 0
LOCATION CONTACT: Virendar Kumar

OWNER NAME: Tanks Data
OWNER ADDRESS: 0
OWNER CITY/STATE/ZIP: 0
LOCATION FID#: 02808
WORK ORDER NO: NE-0559

DSL SPILL BUCKET START 12.5"



DSL SPILL BUCKET END 12.5"



KER SPILL BUCKET TEST START 14"



KER SPILL BUCKET TEST END 14"





CERTIFICATION AFFIDAVIT

August 28, 2023

Tanks Data

0

0

Testing Date: 8/28/2023

Brothers Stop N Go

Location of Test: 1701 W Jefferson

Plymouth, IN 46563

Site FID#: 02808

Service Technician:

0

Certified Technician: CHRIS HOWARD

Midwest ECS has completed the following tests/inspections at the above noted location:

ATG Functionality	
Leak Detector	
Elec Line Leak Detector	
Product Line Testing	
Liquid Sensor Functionality	
Spill Bucket	X
Containment Hydrostatic Sump	
Overfill Equipment Inspection	
Overfill Alarm	X
Vent Valve	
Interstitial	
Non-Volumetric Tank Tightness	
Shear Valve Inspection	

I, Chris Howard, the certified technician, was present throughout the duration of the testing and/or inspection performed by Midwest ECS at the above address on the above date. I affirm that the testing was done in accordance with Rule 329 IAC 9 and 40CFR Part 80, is accurate based upon the results received and that these forms accurately reflects the results of the testing and/or inspection.

Technician Signature: _____

Chris Howard

Technician Printed Name: _____ CHRIS HOWARD

Date & Time: 98-28-2023 12:00



INDIANA HOMELAND SECURITY

Underground Storage Tank

CHRISTOPHER HOWARD
8923 LIMBERLOST COURT
CAMBY, INDIANA

STATE/PERMIT # UC111000

ISSUE 08/18/2022

EFFECTIVE 08/18/2022

EXPIRATION 08/18/2024

DISCIPLINES

- ☐ Installation or Retrofitting ☐ Decommissioning Closure
☐ Cathodic Protection ☐ Decommissioning Removal
☒ Testing



INDIANA HOMELAND SECURITY

Underground Storage Tank

CHRISTOPHER HOWARD
8923 LIMBERLOST COURT
CAMBY, INDIANA

STATE/PERMIT # UC111468

ISSUE 10/06/2022

EFFECTIVE 10/07/2022

EXPIRATION 10/06/2024

DISCIPLINES

- ☒ Installation or Retrofitting ☐ Decommissioning Closure
☐ Cathodic Protection ☐ Decommissioning Removal
☐ Testing

I attest with my signature below, that this technician was present on site for testing as described above.