



APPENDIX C-3
SPILL BUCKET INTEGRITY TESTING HYDROSTATIC TEST METHOD
SINGLE- AND DOUBLE-WALLED VACUUM TEST METHOD

TEST DATE:	8/28/2023	OWNER NAME:	Tanks Data
LOCATION NAME:	Brothers Stop N Go	OWNER ADDRESS:	0
LOCATION ADDRESS:	1701 W Jefferson	OWNER CITY/STATE/ZIP:	0
LOCATION CITY/STATE:	Plymouth, IN 46563		
LOCATION PHONE:	0	LOCATION FID#:	02808
LOCATION CONTACT:	Virendar Kumar	WORK ORDER NO:	NE-0559

This procedure is to test the leak integrity of single- and double-walled spill buckets. See PEI/RP1200 Section 6.2 for hydrostatic test method. Section 6.3 for single-walled vacuum test method and Section 6.4 for double-walled vacuum test method.

Tank Number	1	2	3	4	5	
Product Stored	RUL 1	RUL 2	PUL	DSL	KER	
Spill Bucket Capacity	5 GALLON	5 GALLON	5 GALLON	5 GALLON	5 GALLON	
Manufacturer	EBW	OPW	EBW	OPW	OPW	
Construction	Single-Walled	Single-Walled	Single-Walled	Single-Walled	Single-Walled	-
Test Type	Hydrostatic	Hydrostatic	Hydrostatic	Hydrostatic	Hydrostatic	-
Spill Bucket Type	Product	Product	Product	Product	Product	-
Liquid & Debris Removed From Spill Bucket?*	YES	YES	YES	YES	YES	-
Visual Inspection (No cracks, loose parts, or separation of the bucket from the fill pipe)	PASS	PASS	PASS	PASS	PASS	-
Tank riser cap included in test?	YES	YES	YES	YES	YES	-
Drain valve included in test?	YES	YES	YES	YES	YES	
Starting Level	6.5	15	7.5	12.5	14	
Test Start Time	12:30	12:30	12:30	12:30	0.5208	
Ending Level	6.5	14.5	6	12.5	14	
Test End Time	1:30	1:30	1:30	1:30	1:30	
Test Period	1HR	1HR	1HR	1HR	1HR	
Level Change	0	-0.5	-1.5	0	0	

Pass/Fail criteria: Must pass vision inspection. Hydrostatic: Water level drop of less than 1/8 inch; Vacuum single-walled only: Maintain at least 26 inches water column; Vacuum double-walled maintain at least 12 inches water column.

TEST RESULTS	PASS	FAIL	FAIL	PASS	PASS	-
--------------	------	------	------	------	------	---

COMMENTS:

* All liquids and debris must be disposed of properly

0

SERVICE TECHNICIAN NAME (printed)

CHRIS HOWARD

CERTIFIED TECHNICIAN NAME (printed)

SERVICE TECHNICIAN SIGNATURE

Chris Howard

CERTIFIED TECHNICIAN SIGNATURE

CERT NO: 30, U1-UC111458

EXPIRATION DATE: 8/18/2024, 10/06