

Mistaken

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 2808		Contact Number
Facility Name <i>Meridian</i>		Contact email
Address <i>1701 W Jefferson St, Plymouth</i>		Date of Inspection <i>05-10-25</i>
Operator on Duty Name <i>JM-246363</i>		Name of the Person Conducting Inspection <i>Meridian Long</i>
Operator Training		
Operator Training current ☐ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No		
Is Registration current with correct owner, operator etc. ☐ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No		
Registration/Notification Form		
Release Detection Method ☒ ATG ☐ CIM ☐ SIR ☐ IC ☐ Other		
Make and Model <i>VR-TLS350</i>		
Does it have paper? ☒ Yes ☐ No ☐ Operator Notified ☒ Yes ☐ No		
Is it in Alarm mode? ☒ Yes ☐ No ☐ Operator Notified ☒ Yes ☐ No		
Interstitial Monitoring Sensor Status Normal ☐ Yes ☐ No ☐ Operator Notified ☒ Yes ☐ No		
Necessary Monthly Printout Taken ☐ Yes ☐ No ☐ Operator Notified ☒ Yes ☐ No		
Spill Buckets		
Are Spill Buckets Clean and free from water, debris, product etc? ☒ Yes ☐ No ☐ Operator Notified ☒ Yes ☐ No		
Are the Spill Bucket in good condition and free of damage/cracks ☒ Yes ☐ No ☐ Operator Notified ☒ Yes ☐ No		
Fill Ports		
Is Fill pipe cap tight and fill pipe free from any obstruction? ☐ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No		
Piping/STP Sumps		
Are Sumps Clean and free from water, debris, product etc? ☐ Yes ☐ No ☐ Operator Notified ☒ Yes ☐ No		
Under Dispenser Containments (UDC)		
Are UDCs clean and free from water, debris, product etc? ☐ Yes ☐ No ☐ Operator Notified ☒ Yes ☐ No		
NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.		
Operator on Duty Name		Signature
317-645-0215		Date
tanksdata@gmail.com		www.tanksdata.com