

01/04/25 6:12 PM

Hoke's
1701 W Jefferson st
Plymouth, IN 46563
J11203417608002

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 1: RUL N

REPORT TYPE = LAST GROSS
DATE/TIME = 01/04/25 5:56
METHOD = SLD Gross Test
AVG. VOLUME = 5642
% VOLUME = 35.7

REPORT TYPE = LAST PERIODIC
DATE/TIME = 01/04/25 6:35
METHOD = CSLD Periodic Test
HOURS = 51
AVG. VOLUME = 11223
% VOLUME = 71.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/01/25 21:22
METHOD = CSLD Periodic Test
HOURS = 49
AVG. VOLUME = 11508
% VOLUME = 72.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/31/24 1:26
METHOD = CSLD Periodic Test
HOURS = 49
AVG. VOLUME = 11508
% VOLUME = 72.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/04/24 0:23
METHOD = CSLD Periodic Test
HOURS = 36
AVG. VOLUME = 9505
% VOLUME = 60.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/27/24 9:01
METHOD = CSLD Periodic Test
HOURS = 34
AVG. VOLUME = 9788
% VOLUME = 61.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/22/24 6:39
METHOD = CSLD Periodic Test
HOURS = 34
AVG. VOLUME = 9144
% VOLUME = 57.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/14/24 0:42
METHOD = CSLD periodic Test
HOURS = 42
AVG. VOLUME = 9016
% VOLUME = 57.0

01/04/25 6:14 PM

Hoke's
1701 W Jefferson st
Plymouth, IN 46563
J11203417608002

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 2: RUL S

REPORT TYPE = LAST GROSS
DATE/TIME = 01/04/25 5:56
METHOD = SLD Gross Test
AVG. VOLUME = 6334
% VOLUME = 98.6

REPORT TYPE = LAST PERIODIC
DATE/TIME = 01/04/25 6:35
METHOD = CSLD Periodic Test
HOURS = 96
AVG. VOLUME = 4921
% VOLUME = 76.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/01/25 6:30
METHOD = CSLD Periodic Test
HOURS = 98
AVG. VOLUME = 4927
% VOLUME = 76.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/02/24 22:15
METHOD = CSLD Periodic Test
HOURS = 50
AVG. VOLUME = 5950
% VOLUME = 92.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/01/24 0:37
METHOD = CSLD Periodic Test
HOURS = 47
AVG. VOLUME = 5968
% VOLUME = 92.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/01/24 0:50
METHOD = CSLD Periodic Test
HOURS = 44
AVG. VOLUME = 5983
% VOLUME = 93.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/01/24 4:42
METHOD = CSLD Periodic Test
HOURS = 51
AVG. VOLUME = 5993
% VOLUME = 93.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/01/24 21:54
METHOD = CSLD Periodic Test
HOURS = 27

01/04/25 6:14 PM

Hoke's
1701 W Jefferson st
Plymouth, IN 46563
J11203417608002

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 3: PRM

REPORT TYPE = LAST PERIODIC
DATE/TIME = 01/04/25 17:35
METHOD = CSLD Periodic Test
HOURS = 51
AVG. VOLUME = 1670
% VOLUME = 20.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/01/25 6:46
METHOD = CSLD Periodic Test
HOURS = 55
AVG. VOLUME = 1917
% VOLUME = 23.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/02/24 11:12
METHOD = CSLD Periodic Test
HOURS = 37
AVG. VOLUME = 2579
% VOLUME = 31.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/30/24 19:42
METHOD = CSLD Periodic Test
HOURS = 34
AVG. VOLUME = 2567
% VOLUME = 31.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/08/24 9:38
METHOD = CSLD Periodic Test
HOURS = 37
AVG. VOLUME = 2147
% VOLUME = 26.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/01/24 1:41
METHOD = CSLD Periodic Test
HOURS = 38
AVG. VOLUME = 1856
% VOLUME = 22.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/01/24 3:22
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 2148
% VOLUME = 26.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/25/24 16:01
METHOD = CSLD Periodic Test
HOURS = 32

01/04/25 6:14 PM

Hoke's
1701 W Jefferson st
Plymouth, IN 46563
J11203417608002

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 4: DSL

REPORT TYPE = LAST PERIODIC
DATE/TIME = 01/04/25 16:33
METHOD = CSLD Periodic Test
HOURS = 65
AVG. VOLUME = 1409
% VOLUME = 33.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/01/25 2:05
METHOD = CSLD Periodic Test
HOURS = 49
AVG. VOLUME = 1638
% VOLUME = 39.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/13/24 8:08
METHOD = CSLD Periodic Test
HOURS = 45
AVG. VOLUME = 2555
% VOLUME = 61.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/27/24 20:06
METHOD = CSLD Periodic Test
HOURS = 44
AVG. VOLUME = 2425
% VOLUME = 57.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/09/24 21:00
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 2300
% VOLUME = 54.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/04/24 11:47
METHOD = CSLD Periodic Test
HOURS = 47
AVG. VOLUME = 2215
% VOLUME = 52.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/08/24 4:25
METHOD = CSLD Periodic Test
HOURS = 36
AVG. VOLUME = 2346
% VOLUME = 56.0

REPORT TYPE = FULLEST PERIODIC

01/04/25 6:14 PM

Hoke's
1701 W Jefferson st
Plymouth, IN 46563
J11203417608002

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 5: KERO

REPORT TYPE = LAST PERIODIC
DATE/TIME = 01/04/25 17:17
METHOD = CSLD Periodic Test
HOURS = 59
AVG. VOLUME = 1465
% VOLUME = 36.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/01/25 0:45
METHOD = CSLD Periodic Test
HOURS = 52
AVG. VOLUME = 1494
% VOLUME = 37.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/01/24 12:01
METHOD = CSLD Periodic Test
HOURS = 65
AVG. VOLUME = 2051
% VOLUME = 51.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/01/24 2:53
METHOD = CSLD Periodic Test
HOURS = 89
AVG. VOLUME = 2256
% VOLUME = 56.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/08/24 10:32
METHOD = CSLD Periodic Test
HOURS = 120
AVG. VOLUME = 2301
% VOLUME = 57.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/30/24 23:51
METHOD = CSLD Periodic Test
HOURS = 86
AVG. VOLUME = 1654
% VOLUME = 41.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/07/24 8:00
METHOD = CSLD periodic Test
HOURS = 82
AVG. VOLUME = 454
% VOLUME = 11.4