

05/12/25 3:12 PM

Skate's
701 W Jefferson St
Plymouth, IN 46563
11203417608002

WANK LEAK TEST HISTORY - PASSED TEST RESULTS

11 RUL N

REPORT TYPE = LAST GROSS
DATE/TIME = 05/12/25 5:01
METHOD = SLD Gross Test
VG. VOLUME = 13777
VOLUME = 87.1

REPORT TYPE = LAST PERIODIC
DATE/TIME = 05/12/25 4:36
METHOD = CSLD Periodic Test
DURS = 29
VG. VOLUME = 8272
VOLUME = 52.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/04/25 4:35
METHOD = CSLD Periodic Test
DURS = 30
VG. VOLUME = 8497
VOLUME = 53.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/01/25 21:23
METHOD = CSLD Periodic Test
DURS = 32
VG. VOLUME = 8924
VOLUME = 56.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/26/25 21:50
METHOD = CSLD Periodic Test
DURS = 28
VG. VOLUME = 10155
VOLUME = 64.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/03/25 1:17
METHOD = CSLD Periodic Test
DURS = 39
VG. VOLUME = 9284
VOLUME = 58.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/13/25 0:50
METHOD = CSLD Periodic Test
DURS = 42
VG. VOLUME = 11511
VOLUME = 72.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/31/24 1:26
METHOD = CSLD Periodic Test
DURS = 49
VG. VOLUME = 11508
VOLUME = 72.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/04/24 0:23
METHOD = CSLD Periodic Test
DURS = 36
VG. VOLUME = 9505
VOLUME = 60.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/27/24 9:01
METHOD = CSLD Periodic Test
DURS = 34
VG. VOLUME = 9788
VOLUME = 61.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/22/24 6:39

05/12/25 3:12 PM

Boke's
701 W Jefferson St
Plymouth, IN 46563
11203417608002

TANK LEAK TEST HISTORY
PASSED TEST RESULTS

2: RUL 5

REPORT TYPE = LAST GROSS
DATE/TIME = 05/12/25 5:01
METHOD = SLD Gross Test
VG. VOLUME = 6339
VOLUME = 98.7

REPORT TYPE = LAST PERIODIC
DATE/TIME = 05/12/25 4:04
METHOD = CSLD Periodic Test
HOURS = 117
VG. VOLUME = 6338
VOLUME = 98.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/12/25 4:04
METHOD = CSLD Periodic Test
HOURS = 117
VG. VOLUME = 6338
VOLUME = 98.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/30/25 3:56
METHOD = CSLD Periodic Test
HOURS = 96
VG. VOLUME = 6337
VOLUME = 98.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/31/25 4:03
METHOD = CSLD Periodic Test
HOURS = 99
VG. VOLUME = 6336
VOLUME = 98.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/05/25 3:58
METHOD = CSLD Periodic Test
HOURS = 58
VG. VOLUME = 6335
VOLUME = 98.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/31/25 4:20
METHOD = CSLD Periodic Test
HOURS = 56
VG. VOLUME = 6335
VOLUME = 98.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/02/24 22:15
METHOD = CSLD Periodic Test
HOURS = 50
VG. VOLUME = 5950
VOLUME = 92.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/01/24 0:37
METHOD = CSLD Periodic Test
HOURS = 47
VG. VOLUME = 5968
VOLUME = 92.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/01/24 0:50
METHOD = CSLD Periodic Test
HOURS = 44
VG. VOLUME = 5983
VOLUME = 93.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/01/24 4:42
METHOD = CSLD Periodic Test
HOURS = 51
VG. VOLUME = 5997
VOLUME = 92.9

05/12/25 3:13 PM

Mike's
701 W Jefferson St
Bloomington, IN 46563
1203417608002

TANK LEAK TEST HISTORY PASSED TEST RESULTS

3: PRM

REPORT TYPE = LAST PERIODIC
DATE/TIME = 05/12/25 14:31
METHOD = CSLD Periodic Test
DURATION = 39
VG. VOLUME = 1817
VOLUME = 22.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/11/25 11:21
METHOD = CSLD Periodic Test
DURATION = 36
VG. VOLUME = 1918
VOLUME = 23.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/30/25 2:13
METHOD = CSLD Periodic Test
DURATION = 29
VG. VOLUME = 1787
VOLUME = 21.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/02/25 19:29
METHOD = CSLD Periodic Test
DURATION = 38
VG. VOLUME = 1939
VOLUME = 23.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/18/25 5:23
METHOD = CSLD Periodic Test
DURATION = 33
VG. VOLUME = 2286
VOLUME = 27.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/19/25 4:31
METHOD = CSLD Periodic Test
DURATION = 46
VG. VOLUME = 1964
VOLUME = 23.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/02/24 11:12
METHOD = CSLD Periodic Test
DURATION = 37
VG. VOLUME = 2579
VOLUME = 31.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/30/24 19:42
METHOD = CSLD Periodic Test
DURATION = 34
VG. VOLUME = 2567
VOLUME = 31.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/08/24 9:38
METHOD = CSLD Periodic Test
DURATION = 37
VG. VOLUME = 2147
VOLUME = 26.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/01/24 1:41
METHOD = CSLD Periodic Test
DURATION = 38
VG. VOLUME = 1856
VOLUME = 22.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/01/24 3:22
METHOD = CSLD Periodic Test
DURATION = 35
VG. VOLUME = 2148
VOLUME = 26.0

7/12/25 3:10 PM

01 W Jefferson St
Yonkers, IN 46563
1203417600002

LEAK TEST HISTORY CSLD TEST RESULTS

4: DSL

PORT TYPE = LAST PERIODIC
TE/TIME = 05/12/25 14:24
THOD = CSLD Periodic Test
URS = 42
G. VOLUME = 1698
VOLUME = 40.5

PORT TYPE = FULLEST PERIODIC
TE/TIME = 05/03/25 8:16
THOD = CSLD Periodic Test
URS = 38
G. VOLUME = 1868
VOLUME = 44.6

PORT TYPE = FULLEST PERIODIC
TE/TIME = 04/10/25 5:41
THOD = CSLD Periodic Test
URS = 40
G. VOLUME = 1915
VOLUME = 45.7

PORT TYPE = FULLEST PERIODIC
TE/TIME = 03/16/25 15:54
THOD = CSLD Periodic Test
URS = 44
G. VOLUME = 2191
VOLUME = 52.3

PORT TYPE = FULLEST PERIODIC
TE/TIME = 02/01/25 6:40
THOD = CSLD Periodic Test
URS = 33
G. VOLUME = 1977
VOLUME = 47.2

PORT TYPE = FULLEST PERIODIC
TE/TIME = 01/31/25 10:23
THOD = CSLD Periodic Test
URS = 33
G. VOLUME = 1977
VOLUME = 47.2

PORT TYPE = FULLEST PERIODIC
TE/TIME = 12/13/24 8:08
THOD = CSLD Periodic Test
URS = 45
G. VOLUME = 2555
VOLUME = 61.0

PORT TYPE = FULLEST PERIODIC
TE/TIME = 11/27/24 20:06
THOD = CSLD Periodic Test
URS = 44
G. VOLUME = 2425
VOLUME = 57.9

PORT TYPE = FULLEST PERIODIC
TE/TIME = 10/09/24 21:00
THOD = CSLD Periodic Test
URS = 33
G. VOLUME = 2300
VOLUME = 54.9

PORT TYPE = FULLEST PERIODIC
TE/TIME = 09/04/24 11:47
THOD = CSLD Periodic Test
URS = 47
G. VOLUME = 2215
VOLUME = 52.9

PORT TYPE = FULLEST PERIODIC
TE/TIME = 08/08/24 4:25
THOD = CSLD Periodic Test
URS = 36
G. VOLUME = 2346
VOLUME = 56.0

REPORT TYPE = FULLEST PERIODIC

7/25 3:13 PM

5
W Jefferson st
uth, IN 46563
3417608002

LEAK TEST HISTORY -
ED TEST RESULTS

KERO

RT TYPE = LAST PERIODIC
/TIME = 04/18/25 8:00
OD = CSLD Periodic Test
S = 20
VOLUME = 457
LUME = 11.4

RT TYPE = FULLEST PERIODIC
/TIME = 04/12/25 8:00
OD = CSLD Periodic Test
S = 72
VOLUME = 461
LUME = 11.5

RT TYPE = FULLEST PERIODIC
/TIME = 03/01/25 12:51
OD = CSLD Periodic Test
S = 67
VOLUME = 568
LUME = 14.2

RT TYPE = FULLEST PERIODIC
/TIME = 02/01/25 2:16
OD = CSLD Periodic Test
S = 74
VOLUME = 897
LUME = 22.4

RT TYPE = FULLEST PERIODIC
/TIME = 01/01/25 0:45
OD = CSLD Periodic Test
S = 52
VOLUME = 1494
LUME = 37.3

RT TYPE = FULLEST PERIODIC
/TIME = 12/01/24 12:01
OD = CSLD Periodic Test
S = 65
VOLUME = 2051
LUME = 51.3

RT TYPE = FULLEST PERIODIC
/TIME = 11/01/24 2:53
OD = CSLD Periodic Test
S = 89
VOLUME = 2256
LUME = 56.4

RT TYPE = FULLEST PERIODIC
/TIME = 10/08/24 10:32
OD = CSLD Periodic Test
S = 120
VOLUME = 2301
LUME = 57.5

RT TYPE = FULLEST PERIODIC
/TIME = 09/30/24 23:51
OD = CSLD Periodic Test
S = 86
VOLUME = 1654
LUME = 41.4

RT TYPE = FULLEST PERIODIC
/TIME = 04/07/24 8:00
OD = CSLD Periodic Test
S = 82
VOLUME = 454
LUME = 11.4

RT TYPE = FULLEST PERIODIC
/TIME = 03/01/24 1:37
OD = CSLD Periodic Test
S = 68
VOLUME = 509
LUME = 12.7

RT TYPE = FULLEST PERIODIC
/TIME = 02/01/24 0:56
OD = CSLD Periodic Test
S = 56
VOLUME = 656
LUME = 16.4

RT TYPE = FULLEST PERIODIC
/TIME = 01/01/24 11:48
OD = CSLD Periodic Test
S = 43
VOLUME = 1206
LUME = 30.2

RT TYPE = FULLEST PERIODIC
/TIME = 12/01/23 14:05
OD = CSLD Periodic Test
S = 62