

JINTOIAN MOBIL
JINTOIAN MOBIL
29096 CR 20
ELKHART, IN 46517
USA
06/07/2023 13:06:19
SENSOR REPORT
Last Available
2 WIRE SENSOR
UNLEADED STP SUPP
On
06/07/2023 13:06:19
PREMIUM STP SUPP
On
06/07/2023 13:06:19
DIESEL STP SUPP
On
06/07/2023 13:06:19
KERO STP SUPP SENSOR
On
06/07/2023 13:06:19
3 WIRE SENSOR
INTERSTITIAL RUL/PHL
On
06/07/2023 13:06:19
INTERSTITIAL DSL/KERO
On
06/07/2023 13:06:19
MAG SENSOR

No Records Found

JINTOIAN MOBIL
JINTOIAN MOBIL
29096 CR 20
ELKHART, IN 46517
USA
06/07/2023 13:06:55
SCALO REPORT
Last Available
units:gal, in, °F

TANKS

UNLEADED
UNLEADED
Capacity: 11,608.8
Begin End
05/23/2023 06/04/2023
05:11:23 06:39:02
Result Pass
Slope 0.88
Status 95
Volume Qualify % >= 14
PREMIUM
PREMIUM
Capacity: 3,765.8
Begin End
06/07/2023 06/07/2023
08:35:14 10:35:24
Result Pass
Slope -0.83
Status 0
Volume Qualify % >= 14
DIESEL
DIESEL
Capacity: 6,044.8
Begin End
06/07/2023 06/07/2023
11:31:24 12:59:00
Result Pass
Slope -0.82
Status 0
Volume Qualify % >= 14
KEROSENE
KEROSENE
Capacity: 3,765.8
Begin End
05/20/2021 06/20/2021
18:16:32 19:42:48
Result Pass
Slope 0.88
Status 0
Volume Qualify % >= 14

JINTOIAN MOBIL
JINTOIAN MOBIL
29096 CR 20
ELKHART, IN 46517
USA
06/07/2023 13:07:26
TANK TEST REPORT
Last Available
units:gal, in, °F

TANKS

UNLEADED
UNLEADED
Capacity 11,608.8
Begin End
02/01/2019 02/01/2019
15:33:09 15:33:18
-----Gross-----
4,898.6 4,898.5
-----Water Level-----
0.95 0.95
-----Water Volume-----
19.3 19.3
-----Net-----
4,998.5 4,998.4
-----Level-----
39.79 39.79
-----Temperature-----
38.74 38.74
Last Delivery
01/30/2019 01:49:27
Test Type Annual
Threshold 0.85
Leak Rate 0.88
Result Reported
Capacity(%) 47.13
PREMIUM
PREMIUM
Capacity 3,765.8
Begin End
01/31/2019 01/31/2019
18:57:13 18:57:22
-----Gross-----
1,922.6 1,922.6
-----Water Level-----
0.75 0.75
-----Water Volume-----
5.8 5.8
-----Net-----
1,951.9 1,951.9
-----Level-----
46.86 46.86
-----Temperature-----
35.33 35.33