

UST TESTING/INSPECTION RESULTS SUMMARY

OWNER NAME: New Punjab LLC
 OWNER ADDRESS: 29026 State Road 20
 OWNER CITY/STATE/ZIP: Elkhart, IN 46517

TESTING DATE: 10/10/2023

LOCATION NAME: Midwest Petro
 LOCATION ADDRESS: 29026 State Road 20
 LOCATION CITY/STATE: Elkhart, IN 46517
 LOCATION FID#: 25595

METHOD OF TANK LEAK DETECTION -
 METHOD OF PIPING LEAK DETECTION -
 TYPE OF UNDERGROUND PIPING -

ANNUAL TESTING/INSPECTIONS

AUTOMATIC TANK GAUGE TEST

NOT PERFORMED

TANK NO	PRODUCT	BRAND/MODEL	RESULT

PRODUCT LINE TEST

COMPLETED

Product line must be within manufacturer's criteria of +/- .050 GPH.

LINE NO	PRODUCT	RESULT	AMT OF CHG/GPH
1	RUL	PASS	-0.0296
2	PUL	PASS	-0.0296
3	DSL	PASS	-0.0444

LEAK DETECTOR TEST

COMPLETED

LINE NO	PRODUCT	TYPE	RESULT
1	RUL	ELLD	PASS
0	0	ELLD	PASS
3	DSL	ELLD	PASS

LIQUID SENSOR FUNCTIONALITY TEST

NOT PERFORMED

LOCATION	PRODUCT	TYPE	RESULT

LEGEND:

RUL	Regular Unleaded
DSL	Diesel
PUL	Premium Unleaded
KER	Kerosene
ODSL	Off Road Diesel
REC	Recreational

RECOMMENDATIONS:

SITE PHOTOS

TEST DATE: 10/10/2023
LOCATION NAME: Midwest Petro
LOCATION ADDRESS: 29026 State Road 20
LOCATION CITY/STATE: Elkhart, IN 46517
LOCATION PHONE: 317-645-0215
LOCATION CONTACT: Tanks Data / Virendar Kumar

OWNER NAME: New Punjab LLC
OWNER ADDRESS: 29026 State Road 20
OWNER CITY/STATE/ZIP: Elkhart, IN 46517
LOCATION FID#: 25595
WORK ORDER NO: NE-0760

RUL ATG PROBE TEST



PUL ATG PROBE TEST



DSL ATG PROBE TEST



KER ATG PROBE TEST





CERTIFICATION VERIFICATION

New Punjab LLC
29026 State Road 20
Elkhart, IN 46517

0

Testing Date: 10/10/2023
Midwest Petro
Location of Test: 29026 State Road 20
Elkhart, IN 46517
Site FID#: 25595
Service Technician:
Certified Technician: PATRICK FOLEY

0

Midwest ECS has completed the following tests/inspections at the above noted location:

ATG Functionality	
Leak Detector	
Elec Line Leak Detector	X
Product Line Testing	X
Liquid Sensor Functionality	
Spill Bucket	
Containment Hydrostatic Sump	
Overfill Equipment Inspection	
Overfill Alarm	
Vent Valve	
Interstitial	
Non-Volumetric Tank Tightness	
Shear Valve Inspection	X

I, PATRICK FOLEY, the certified technician, was present throughout the duration of the testing and/or inspection performed by Midwest ECS at the above address on the above date. I affirm that the testing was done in accordance with Rule 329 IAC 9 and 40CFR Part 80, is accurate based upon the results received and that these forms accurately reflect the results of the testing and/or inspection.

Technician Signature:

Technician Printed Name:

PATRICK FOLEY

Date & Time:

10/10/2023 10:01



INDIANA HOMELAND SECURITY
Underground Storage Tank
PATRICK FOLEY
602 S 21ST STREET
LAFAYETTE, INDIANA

STATE/PERMIT #
UC111246

ISSUE
09/16/2022

EFFECTIVE
09/16/2022

EXPIRATION
09/15/2024

☒ Installation or Retrofitting

☐ Decommissioning Closure

☐ Cathodic Protection

☐ Decommissioning Removal



I attest with my signature below, that this technician was present onsite for testing as described above.