

APPENDIX C-5
UT OVERFILL EQUIPMENT INSPECTION
AUTOMATIC SHUTOFF DEVICE AND BALL FLOAT VALVE

TEST DATE: 10/10/2023
LOCATION NAME: Midwest Petro
LOCATION ADDRESS: 29026 State Road 20
LOCATION CITY/STATE: Elkhart, IN 46517
LOCATION PHONE: 317-645-0215
LOCATION CONTACT: Tanks Data / Virendar Kumar

OWNER NAME: New Punjab LLC
OWNER ADDRESS: 29026 State Road 20
OWNER CITY/STATE/ZIP: Elkhart, IN 46517
LOCATION FID#: 25595
WORK ORDER NO: NE-0761

This data sheet is for inspection automatic shutoff devices and ball float valves. See PEI/RP1200 Section 7 for inspection procedures.

Product Grade	RUL	PUL	DSL	KER		
Tank Number	1	2	3	4		
Tank Volume, gallons	11608	3765	6044	3765		
Tank Diameter, inches	90"	90"	90"	90"		
Overfill Prevention Device Brand	FRANKLIN	FRANKLIN	FRANKLIN	FRANKLIN		
Type	Automatic Shutoff Valve	Automatic Shutoff Valve	Automatic Shutoff Valve	Automatic Shutoff Valve	-	-

AUTOMATIC SHUTOFF DEVICE INSPECTION

1. Drop tube removed from tank?	YES	YES	YES	YES		
2. Drop tube and float mechanisms free of debris?	YES	YES	YES	YES		
3. Float moves freely without binding and poppet moves into flow path?	YES	YES	YES	YES		
4. Bypass valve in the drop tube open and free of blockage (if present)?	NOT PRESENT	NOT PRESENT	NOT PRESENT	NOT PRESENT		
5. Flapper adjusted to shut off flow at 95% capacity?*	YES	YES	YES	YES		

BALL FLOAT VALVE INSPECTION **

1. Tank Top fitting vapor-tight and leak-free?						
2. Ball float cage free of debris?						
3. Ball free of holes and cracks and moves freely in cage?						
4. Vent hole in pipe open and near top of tank?						
5. Ball float pipe proper length to restrict flow at 90% capacity?***						

A "No" to any item in Lines 1-5 indicates a test failure.

AUTO SHUT OFF DEVICE TEST RESULTS	PASS	PASS	PASS	PASS		
BALL FLOAT VALVE INSPECTION RESULTS						

COMMENTS:

* Use manufacturer's suggested procedure for determining if automatic shutoff device will shut off flow at 95% capacity.

** If a ball float is found to fail in inspection, another method of overfill must be used.

*** Use manufacturer's suggested procedure for determining if flow restriction device will restrict flow at 90% capacity.

0

SERVICE TECHNICIAN NAME (printed)

ADAM WILDER

CERTIFIED TECHNICIAN NAME (printed)

SERVICE TECHNICIAN SIGNATURE



CERTIFIED TECHNICIAN SIGNATURE

CERT NO: UC112310

EXPIRATION DATE: 01/23/2025