

JIMTOWN MOBIL
JIMTOWN MOBIL
29096 CR 20
ELKHART, IN 46517
USA
01/28/2025 18:20:31

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

UNLEADED
UNLEADED
Capacity: 11,608.0

Begin	End
01/10/2025 15:41:51	01/25/2025 16:43:59
Result	Pass
Slope	-0.06
Status	99
Volume Qualify %	>= 14

PREMIUM
PREMIUM
Capacity: 3,765.0

Begin	End
01/28/2025 04:15:25	01/28/2025 06:35:24
Result	Pass
Slope	0.02
Status	0
Volume Qualify %	>= 14

DIESEL
DIESEL
Capacity: 6,044.0

Begin	End
01/28/2025 14:16:57	01/28/2025 16:44:00
Result	Pass
Slope	0.10
Status	0
Volume Qualify %	>= 14

KEROSENE
KEROSENE
Capacity: 3,765.0

Begin	End
06/20/2021 18:16:32	06/20/2021 19:42:48
Result	Pass
Slope	0.00
Status	0
Volume Qualify %	>= 14

.....

JIMTOWN MOBIL
JIMTOWN MOBIL
29096 CR 20
ELKHART, IN 46517
USA
01/28/2025 18:20:37

REGULATORY REPORT
(Passed Tests)
January 2025

units:gph

TANKS (MONTHLY)

Tank 1
UNLEADED
SCALD
Slope -0.06
▶ 01/10/2025 15:41:51
▶ 01/25/2025 16:43:59
Volume Qualify % >= 14

Slope -0.03
▶ 01/02/2025 11:50:27
▶ 01/17/2025 12:34:24
Volume Qualify % >= 14

Tank 2
PREMIUM
SCALD
Slope 0.02
▶ 01/28/2025 04:15:25
▶ 01/28/2025 06:35:24
Volume Qualify % >= 14

Slope 0.01
▶ 01/11/2025 10:02:50
▶ 01/11/2025 11:29:06
Volume Qualify % >= 14

Tank 3
DIESEL
SCALD
Slope 0.10
▶ 01/28/2025 14:16:57
▶ 01/28/2025 16:44:00
Volume Qualify % >= 14

Slope 0.01
▶ 01/08/2025 14:01:47
▶ 01/08/2025 16:31:40
Volume Qualify % >= 14

LINES (MONTHLY)

Line 1
UNLEADED
Normal
01/27/2025 07:55:24
01/19/2025 10:37:00

Line 2
PREMIUM
Normal
01/28/2025 12:36:10
01/06/2025 22:58:21

Line 3
DIESEL
Normal
01/28/2025 03:45:42
01/13/2025 19:21:14

LINES (ANNUAL)

Line 1
UNLEADED
01/26/2025 15:17:28

Line 2
PREMIUM
01/28/2025 01:36:14

Line 3
DIESEL
01/27/2025 22:26:20

2 WIRE SENSOR (MONTHLY)

PREMIUM STP SUMP
01/28/2025 12:00:00
01/09/2025 12:00:00

KERO STP SUMP SENSOR
01/28/2025 12:00:00
01/24/2025 12:00:00

3 WIRE SENSOR (MONTHLY)

INTERSTITIAL RUL/PNL
01/28/2025 12:00:00
01/23/2025 12:00:00

INTERSTITIAL DSL/KERO
01/28/2025 12:00:00
01/24/2025 12:00:00

.....

JIMTOWN MOBIL
JIMTOWN MOBIL
29096 CR 20
ELKHART, IN 46517
USA

01/28/2025 18:20:37

SENSOR REPORT
Last Available

2 WIRE SENSOR

UNLEADED STP SUMP
Alarm
01/28/2025 18:20:37

PREMIUM STP SUMP
Ok
01/28/2025 18:20:37

DIESEL STP SUMP
Alarm
01/28/2025 18:20:37

KERO STP SUMP SENSOR
Ok
01/28/2025 18:20:37

3 WIRE SENSOR

INTERSTITIAL RUL/PNL
Ok
01/28/2025 18:20:37

INTERSTITIAL DSL/KERO
Ok
01/28/2025 18:20:37

MAG SENSOR

No Records Found