

JIMTOWN MOBIL
JIMTOWN MOBIL
29096 CR 20
ELKHART, IN 46517
USA

02/27/2025 18:47:05

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

UNLEADED

UNLEADED

Capacity: 11,608.0

Begin End
02/10/2025 02/25/2025
03:44:11 04:01:33
Result Pass
Slope 0.03
Status 99

Volume Qualify % >= 14

PREMIUM

PREMIUM

Capacity: 3,765.0

Begin End
02/27/2025 02/27/2025
14:50:20 17:46:55
Result Pass
Slope -0.01
Status 0

Volume Qualify % >= 14

DIESEL

DIESEL

Capacity: 6,044.0

Begin End
02/27/2025 02/27/2025
16:05:59 18:00:10
Result Pass
Slope -0.02
Status 0

Volume Qualify % >= 14

KEROSENE

KEROSENE

Capacity: 3,765.0

Begin End
06/20/2021 06/20/2021
18:16:32 19:42:48
Result Pass
Slope 0.00
Status 0

Volume Qualify % >= 14

.....

JIMTOWN MOBIL
JIMTOWN MOBIL
29096 CR 20
ELKHART, IN 46517
USA

02/27/2025 18:47:11

REGULATORY REPORT
(Passed Tests)
February 2025

units:gph

TANKS (MONTHLY)

Tank 1

UNLEADED

SCALD

Slope 0.03

▶ 02/10/2025 03:44:11

▶ 02/25/2025 04:01:33

Volume Qualify % >= 14

Slope -0.03

▶ 02/01/2025 05:16:45

▶ 02/16/2025 04:18:58

Volume Qualify % >= 14

Tank 2

PREMIUM

SCALD

Slope -0.01

▶ 02/27/2025 14:50:20

▶ 02/27/2025 17:46:55

Volume Qualify % >= 14

Slope 0.06

▶ 02/10/2025 08:50:44

▶ 02/10/2025 11:14:55

Volume Qualify % >= 14

Tank 3

DIESEL

SCALD

Slope -0.02

▶ 02/27/2025 16:05:59

▶ 02/27/2025 18:00:10

Volume Qualify % >= 14

Slope 0.04

▶ 02/07/2025 12:59:19

▶ 02/07/2025 14:35:47

Volume Qualify % >= 14

LINES (MONTHLY)

Line 1
UNLEADED
Normal
02/27/2025 04:28:02
02/17/2025 05:24:20

Line 2
PREMIUM
Normal
02/26/2025 20:43:32
02/04/2025 23:24:22

Line 3
DIESEL
Normal
02/27/2025 05:23:36
02/12/2025 01:36:50

LINES (ANNUAL)

Line 1
UNLEADED
02/24/2025 04:12:54

Line 2
PREMIUM
02/25/2025 06:49:14

Line 3
DIESEL
02/25/2025 09:27:54

2 WIRE SENSOR (MONTHLY)

PREMIUM STP SUMP
02/27/2025 12:00:00
02/07/2025 12:00:00

KERO STP SUMP SENSOR
02/27/2025 12:00:00
02/22/2025 12:00:00

3 WIRE SENSOR (MONTHLY)

INTERSTITIAL RUL/PNL
02/27/2025 12:00:00
02/21/2025 12:00:00

INTERSTITIAL DSL/KERO
02/27/2025 12:00:00
02/22/2025 12:00:00

.....

JIMTOWN MOBIL
JIMTOWN MOBIL
29096 CR 20
ELKHART, IN 46517
USA

02/27/2025 18:47:12

SENSOR REPORT

Last Available

2 WIRE SENSOR

UNLEADED STP SUMP
Alarm
02/27/2025 18:47:12

PREMIUM STP SUMP
OK
02/27/2025 18:47:12

DIESEL STP SUMP
Alarm
02/27/2025 18:47:12

KERO STP SUMP SENSOR
OK
02/27/2025 18:47:12

3 WIRE SENSOR

INTERSTITIAL RUL/PNL
OK
02/27/2025 18:47:12

INTERSTITIAL DSL/KERO
OK
02/27/2025 18:47:12

MAG SENSOR