

JIMTOWN MOBIL
JIMTOWN MOBIL
29096 CR 20
ELKHART, IN 46517
USA
04/27/2025 18:28:20

TANK TEST REPORT
Last Available

units:gal, in, °F

TANKS

UNLEADED
UNLEADED
Capacity 11,608.0

Begin	End
02/01/2019 02:01/2019	02/01/2019 15:33:18
15:33:09	15:33:18
-----Gross-----	
4,890.6	4,890.5
-----Water Level-----	
0.95	0.95
-----Water Volume-----	
19.3	19.3
-----Net-----	
4,990.5	4,990.4
-----Level-----	
39.79	39.79
-----Temperature-----	
30.74	30.74

Last Delivery
01/30/2019 01:49:27
Test Type Annual
Threshold 0.05
Leak Rate 0.00
Result Aborted
Capacity(%) 42.13

PREMIUM
PREMIUM
Capacity 3,765.0

Begin	End
01/31/2019 01/31/2019	01/31/2019 18:57:22
18:57:13	18:57:22
-----Gross-----	
1,922.6	1,922.6
-----Water Level-----	
0.75	0.75
-----Water Volume-----	
5.0	5.0
-----Net-----	
1,951.9	1,951.9
-----Level-----	
46.06	46.06
-----Temperature-----	
35.33	35.33

Last Delivery
Test Type Monthly(0.2)
Threshold 0.10
Leak Rate 0.00
Result Aborted
Capacity(%) 51.06

DIESEL
DIESEL
Capacity 6,044.0

Begin	End
02/01/2019 02/01/2019	02/01/2019 14:28:25
14:28:16	14:28:25
-----Gross-----	
1,499.1	1,499.1
-----Water Level-----	
1.15	1.15
-----Water Volume-----	
11.9	11.9
-----Net-----	
1,513.6	1,513.6
-----Level-----	
27.52	27.52
-----Temperature-----	
38.65	38.65

Last Delivery
Test Type Annual
Threshold 0.05
Leak Rate 0.00
Result Aborted
Capacity(%) 24.00

KEROSENE
KEROSENE
Capacity 3,765.0

Begin	End
01/30/2019 01/30/2019	01/30/2019 19:54:55
17:52:31	19:54:55
-----Gross-----	
1,132.3	1,132.4
-----Water Level-----	
1.28	1.28
-----Water Volume-----	
11.1	11.1
-----Net-----	
1,143.0	1,143.1
-----Level-----	
30.95	30.95
-----Temperature-----	
40.79	40.77

Last Delivery
11/29/2018 22:33:44
Test Type Annual
Threshold 0.05
Leak Rate 0.03
Result Pass
Capacity(%) 30.00

Details
01/30/2019 19:52:40
Net 1,143.1
Temperature 40.77
Level 30.95
01/30/2019 18:52:40
Net 1,143.1
Temperature 40.78
Level 30.95
.....

JIMTOWN MOBIL
JIMTOWN MOBIL
29096 CR 20
ELKHART, IN 46517
USA
04/27/2025 18:28:23

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

UNLEADED
UNLEADED
Capacity: 11,608.0

Begin	End
04/14/2025 04/26/2025	04/26/2025 08:13:53
01:30:01	08:13:53
Result	Pass
Slope	-0.04
Status	99
Volume Qualify %	>= 14

PREMIUM
PREMIUM
Capacity: 3,765.0

Begin	End
04/27/2025 04/27/2025	04/27/2025 14:39:36
14:39:36	17:12:18
Result	Pass
Slope	0.07
Status	0
Volume Qualify %	>= 14

DIESEL
DIESEL
Capacity: 6,044.0

Begin	End
04/27/2025 04/27/2025	04/27/2025 10:16:57
10:16:57	17:44:09
Result	Pass
Slope	0.05
Status	0
Volume Qualify %	>= 14

KEROSENE
KEROSENE
Capacity: 3,765.0

Begin	End
06/20/2021 06/20/2021	06/20/2021 18:16:32
18:16:32	19:42:48
Result	Pass
Slope	0.00
Status	0
Volume Qualify %	>= 14

.....

JIMTOWN MOBIL
JIMTOWN MOBIL
29096 CR 20
ELKHART, IN 46517
USA
04/27/2025 18:28:28

LINE LEAK REPORT
Last Available

GROSS TEST

UNLEADED
Gross Leak Test Passed
04/27/2025 17:37:07

PREMIUM
Gross Leak Test Passed
04/27/2025 17:53:53

DIESEL
Gross Leak Test Passed
04/27/2025 17:47:03

JIMTOWN MOBIL
JIMTOWN MOBIL
29096 CR 20
ELKHART, IN 46517
USA

04/27/2025 18:28:39

PUMP STATUS REPORT

units:gal, °F, psi, gph

Pump UNLEADED
State Enabled
Status Ok
Pump On Off
Address: 1
Type: Mag/Eco
Voltage: 211
Current: 0
Power: 0
Frequency: 0
Flow Rate: 0.00
Pressure: 32.01
Temperature: 113.00

CONTROLLER SWITCHES

Product: Gas
Compensation: Comp 0 Least
B Press Inc: Off
Mast-Slave: Off
Auto Restart: Off
Alt Circuit: Off
Exten Run: On
Fault Shut: Off
Old VFC: Off

Pump PREMIUM
State Enabled
Status Ok
Pump On Off
Address: 2
Type: Smart I
Voltage: 209
Cal Voltage: 209
Current: 0.1
Cal Current: 3.4
Power: 20
Cal Power: 620
Frequency: 0
Flow Rate: 0.00

CONTROLLER SWITCHES

Mast-Slave: Off
Auto Restart: Off
Alt Circuit: Off
Exten Run: On
Fault Shut: Off
Fault Read: Off
ByPass: Off

Pump DIESEL
State Enabled
Status Ok
Pump On Off
Address: 3
Type: Mag/Eco
Voltage: 213
Current: 0
Power: 0
Frequency: 0
Flow Rate: 0.00
Pressure: 32.01
Temperature: 95.00

CONTROLLER SWITCHES

Product: Diesel
Compensation: Comp 0 Least
B Press Inc: Off
Mast-Slave: Off
Auto Restart: Off
Alt Circuit: Off
Exten Run: On
Fault Shut: Off
Old VFC: Off

Pump KERO
State Enabled
Status Ok
Pump On Off
Address: 4
Type: Smart I
Voltage: 209
Cal Voltage: 207
Current: 0.1
Cal Current: 3.9
Power: 20
Cal Power: 710
Frequency: 0
Flow Rate: 0.00

CONTROLLER SWITCHES

Mast-Slave: Off
Auto Restart: Off
Alt Circuit: Off
Exten Run: On
Fault Shut: Off
Fault Read: Off
ByPass: Off

JIMTOWN MOBIL
JIMTOWN MOBIL
29096 CR 20
ELKHART, IN 46517
USA
04/27/2025 18:28:40

SENSOR REPORT
Last Available

2 WIRE SENSOR

UNLEADED STP SUMP
Alarm
04/27/2025 18:28:40

PREMIUM STP SUMP
Ok
04/27/2025 18:28:40

DIESEL STP SUMP
Alarm
04/27/2025 18:28:40

KERO STP SUMP SENSOR
Ok
04/27/2025 18:28:40

3 WIRE SENSOR

INTERSTITIAL RUL/PNL
Ok
04/27/2025 18:28:40

INTERSTITIAL DSL/KERO
Ok
04/27/2025 18:28:40

MAG SENSOR

No Records Found

JIMTOWN MOBIL
JIMTOWN MOBIL
29096 CR 20
ELKHART, IN 46517
USA
04/27/2025 18:28:46

REGULATORY REPORT
(Passed Tests)
April 2025

units:gph

TANKS (MONTHLY)

Tank 1
UNLEADED
SCALD
Slope -0.0
▶ 04/14/2025 01:30:01
▶ 04/26/2025 08:13:53
Volume Qualify % >= 1
Slope -0.0
▶ 04/02/2025 06:00:36
▶ 04/16/2025 04:15:32
Volume Qualify % >= 1

Tank 2
PREMIUM
SCALD
Slope 0.0
▶ 04/27/2025 14:39:36
▶ 04/27/2025 17:12:18
Volume Qualify % >= 1
Slope -0.0
▶ 04/11/2025 08:58:22
▶ 04/11/2025 10:24:39
Volume Qualify % >= 1

Tank 3
DIESEL
SCALD
Slope 0.0
▶ 04/27/2025 10:16:57
▶ 04/27/2025 17:44:09
Volume Qualify % >= 1
Slope 0.0
▶ 04/08/2025 09:46:41
▶ 04/08/2025 12:20:20
Volume Qualify % >= 1

LINES (MONTHLY)

Line 1
UNLEADED
Normal
04/27/2025 04:52:05
04/17/2025 05:17:17

Line 2
PREMIUM
Normal
04/26/2025 21:52:07
04/05/2025 08:25:46

Line 3
DIESEL
Normal
04/27/2025 14:46:31
04/11/2025 22:53:35

LINES (ANNUAL)

Line 1
UNLEADED
04/26/2025 07:00:07

Line 2
PREMIUM
04/23/2025 10:10:37

Line 3
DIESEL
04/23/2025 07:59:33

2 WIRE SENSOR (MONTHLY)

PREMIUM STP SUMP
04/27/2025 12:00:00
04/07/2025 12:00:00

KERO STP SUMP SENSOR
04/27/2025 12:00:00
04/22/2025 12:00:00

3 WIRE SENSOR (MONTHLY)

INTERSTITIAL RUL/PNL
04/27/2025 12:00:00
04/21/2025 12:00:00

INTERSTITIAL DSL/KERO
04/27/2025 12:00:00
04/22/2025 12:00:00