

001
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	255595	Contact Number	
Facility Name	MOBILE	Contact email	
Address	29026 County Road 209	Date of Inspection	01/28/25
Operator on Duty Name	Elkhart, IN 46517	Name of the Person Conducting Inspection	AKSMIT

Operator Training		Registration/Notification Form		Release Detection	
Operator Training current	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No	Release Detection Method	☒ ATG ☐ CIM ☐ BIR
Is Registration current with correct owner, operator etc.	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No	Make and Model	FFS 15555 EVO
Does it have paper?	☐ Yes ☐ No	Operator Notified	☒ Yes ☐ No	Does it have paper?	☐ Yes ☐ No
Is it in Alarm mode?	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No	Is it in Alarm mode?	☐ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No	Necessary Monthly Printout Taken	☐ Yes ☐ No
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No	Spill Buckets	☐ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No	Fill Ports	☒ Yes ☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No	Piping/STP Sumps	☐ Yes ☐ No
Are Sumps Clean and free from water, debris, product etc?	☐ Yes ☒ No	Operator Notified	☒ Yes ☐ No	Under Dispenser Containments (UDC)	☐ Yes ☐ No
Are UDCs clean and free from water, debris, product etc?	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No		

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name _____ Signature _____ Date _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com