

JIMTOWN MOBIL  
JIMTOWN MOBIL  
29096 CR 20  
ELKHART, IN 46517  
USA  
03/23/2025 19:24:21

SCALD REPORT  
Last Available

units:gal, in, °F

TANKS

UNLEADED  
UNLEADED  
Capacity: 11,608.0

| Begin            | End        |
|------------------|------------|
| 03/11/2025       | 03/23/2025 |
| 10:43:08         | 10:37:32   |
| Result           | Pass       |
| Slope            | 0.01       |
| Status           | 99         |
| Volume Qualify % | >= 14      |

PREMIUM  
PREMIUM  
Capacity: 3,765.0

| Begin            | End        |
|------------------|------------|
| 03/23/2025       | 03/23/2025 |
| 16:41:15         | 18:07:31   |
| Result           | Pass       |
| Slope            | -0.03      |
| Status           | 0          |
| Volume Qualify % | >= 14      |

DIESEL  
DIESEL  
Capacity: 6,044.0

| Begin            | End        |
|------------------|------------|
| 03/23/2025       | 03/23/2025 |
| 17:06:38         | 18:34:16   |
| Result           | Pass       |
| Slope            | 0.04       |
| Status           | 0          |
| Volume Qualify % | >= 14      |

KEROSENE  
KEROSENE  
Capacity: 3,765.0

| Begin            | End        |
|------------------|------------|
| 06/20/2021       | 06/20/2021 |
| 18:16:32         | 19:42:48   |
| Result           | Pass       |
| Slope            | 0.00       |
| Status           | 0          |
| Volume Qualify % | >= 14      |

.....

JIMTOWN MOBIL  
JIMTOWN MOBIL  
29896 CR 20  
ELKHART, IN 46517  
USA  
03/23/2025 19:24:47

TANK TEST REPORT  
Last Available

units: gal. in. °F  
TANKS

UNLEADED  
UNLEADED  
Capacity 11,600.0  
Begin 02/01/2019 15:33:09 End 02/01/2019 15:33:18  
-----Gross----- 4,890.5  
4,890.6  
-----Water Level----- 0.95  
0.95  
-----Water Volume----- 19.3  
19.3  
-----Net----- 4,990.4  
4,990.5  
-----Level----- 39.79  
39.79  
-----Temperature----- 30.74  
30.74

Last Delivery  
01/30/2019 01:49:27  
Test Type Annual  
Threshold 0.05  
Leak Rate 0.00  
Result Aborted  
Capacity(%) 42.13

PREMIUM  
PREMIUM  
Capacity 3,765.0  
Begin 01/31/2019 18:57:13 End 01/31/2019 18:57:22  
-----Gross----- 1,922.6  
1,922.6  
-----Water Level----- 0.75  
0.75  
-----Water Volume----- 5.0  
5.0  
-----Net----- 1,951.9  
1,951.9  
-----Level----- 46.06  
46.06  
-----Temperature----- 35.33  
35.33

Last Delivery  
Test Type Monthly(0.2)  
Threshold 0.10  
Leak Rate 0.00  
Result Aborted  
Capacity(%) 51.06

DIESEL  
DIESEL  
Capacity 6,044.0  
Begin 02/01/2019 14:28:16 End 02/01/2019 14:28:25  
-----Gross----- 1,499.1  
1,499.1  
-----Water Level----- 1.15  
1.15  
-----Water Volume----- 11.9  
11.9  
-----Net----- 1,513.6  
1,513.6  
-----Level----- 27.52  
27.52  
-----Temperature----- 38.65  
38.65

Last Delivery  
Test Type Annual  
Threshold 0.05  
Leak Rate 0.00  
Result Aborted  
Capacity(%) 24.80

KEROSENE  
KEROSENE  
Capacity 3,765.0  
Begin 01/30/2019 17:52:31 End 01/30/2019 19:54:55  
-----Gross----- 1,132.4  
1,132.3  
-----Water Level----- 1.28  
1.28  
-----Water Volume----- 11.1  
11.1  
-----Net----- 1,143.1  
1,143.0  
-----Level----- 30.95  
30.95  
-----Temperature----- 40.77  
40.79

Last Delivery  
11/29/2018 22:33:44  
Test Type Annual  
Threshold 0.05  
Leak Rate 0.03  
Result Pass  
Capacity(%) 30.08

Details  
01/30/2019 19:52:40  
Net 1,143.1  
Temperature 40.77  
Level 30.95  
01/30/2019 18:52:40  
Net 1,143.1  
Temperature 40.78  
Level 30.95