

JIMTOWN MOBIL
JIMTOWN MOBIL
29096 CR 20
ELKHART, IN 46517
USA
07/23/2025 23:39:20
REGULATORY REPORT
(Passed Tests)
July 2025

units:gph

TANKS (MONTHLY)

Tank 1
UNLEADED
SCALD
Slope -0.06
▶ 07/10/2025 09:37:14
▶ 07/23/2025 05:54:40
Volume Qualify % >= 14

Tank 2
PREMIUM
SCALD
Slope -0.06
▶ 07/23/2025 17:17:57
▶ 07/23/2025 20:48:54
Volume Qualify % >= 14
Slope -0.00
▶ 07/10/2025 04:13:49
▶ 07/10/2025 06:41:17
Volume Qualify % >= 14

Tank 3
DIESEL
SCALD
Slope 0.03
▶ 07/23/2025 20:49:23
▶ 07/23/2025 23:08:09
Volume Qualify % >= 14
Slope -0.01
▶ 07/07/2025 03:34:05
▶ 07/07/2025 06:41:55
Volume Qualify % >= 14

LINES (MONTHLY)

Line 1
UNLEADED
Normal
07/23/2025 06:35:58
07/14/2025 06:29:42

Line 2
PREMIUM
Normal
07/23/2025 12:08:20
07/03/2025 02:23:27

Line 3
DIESEL
Normal
07/23/2025 23:27:40
07/08/2025 20:06:46

LINES (ANNUAL)

Line 1
UNLEADED
07/19/2025 05:29:40

Line 2
PREMIUM
07/19/2025 08:50:48

Line 3
DIESEL
07/19/2025 10:05:12

2 WIRE SENSOR (MONTHLY)

PREMIUM STP SUMP
07/23/2025 12:00:00
07/03/2025 12:00:00

KERO STP SUMP SENSOR
07/23/2025 12:00:00
07/18/2025 12:00:00

3 WIRE SENSOR (MONTHLY)

INTERSTITIAL RUL/PNL
07/23/2025 12:00:00
07/17/2025 12:00:00

INTERSTITIAL DSL/KERO
07/23/2025 12:00:00
07/18/2025 12:00:00

.....

JIMTOWN MOBIL
JIMTOWN MOBIL
29096 CR 20
ELKHART, IN 46517