

JIMTOWN MOBIL
JIMTOWN MOBIL
29096 CR 20
ELKHART, IN 46517
USA

05/25/2025 17:41:58

TANK TEST REPORT
Last Available

units:gal, in, °F

TANKS

UNLEADED
UNLEADED
Capacity 11,608.0

Begin End
02/01/2019 02/01/2019
15:33:09 15:33:18

-----Gross-----
4,890.6 4,890.5

-----Water Level-----
0.95 0.95

-----Water Volume-----
19.3 19.3

-----Net-----
4,990.5 4,990.4

-----Level-----
39.79 39.79

-----Temperature-----
30.74 30.74

Last Delivery
01/30/2019 01:49:27

Test Type Annual
Threshold 0.05

Leak Rate 0.00

Result Aborted

Capacity(%) 42.13

PREMIUM
PREMIUM
Capacity 3,765.0

Begin End
01/31/2019 01/31/2019
18:57:13 18:57:22

-----Gross-----
1,922.6 1,922.6

-----Water Level-----
0.75 0.75

-----Water Volume-----
5.0 5.0

-----Net-----
1,951.9 1,951.9

-----Level-----
46.06 46.06

-----Temperature-----
35.33 35.33

Last Delivery

Test Type Monthly(0.2)

Threshold 0.10

Leak Rate 0.00

Result Aborted

Capacity(%) 51.06

DIESEL
DIESEL
Capacity 6,044.0

Begin End
02/01/2019 02/01/2019
14:28:16 14:28:25

-----Gross-----
1,499.1 1,499.1

-----Water Level-----
1.15 1.15

-----Water Volume-----
11.9 11.9

-----Net-----
1,513.6 1,513.6

-----Level-----
27.52 27.52

-----Temperature-----
38.65 38.65

Last Delivery

Test Type Annual

Threshold 0.05

Leak Rate 0.00

Result Aborted

Capacity(%) 24.00

KEROSENE
KEROSENE
Capacity 3,765.0

Begin End
01/30/2019 01/30/2019
17:52:31 19:54:55

-----Gross-----
1,132.3 1,132.4

-----Water Level-----
1.28 1.28

-----Water Volume-----
11.1 11.1

-----Net-----
1,143.0 1,143.1

-----Level-----
30.95 30.95

-----Temperature-----
40.79 40.77

Last Delivery

11/29/2018 22:33:44

Test Type Annual

Threshold 0.05

Leak Rate 0.03

Result Pass

Capacity(%) 30.08

Details

01/30/2019 19:52:40

Net 1,143.1

Temperature 40.77

Level 30.95

01/30/2019 18:52:40

Net 1,143.1

Temperature 40.78

Level 30.95

.....

JIMTOWN MOBIL

JIMTOWN MOBIL

29096 CR 20

ELKHART, IN 46517

USA

05/25/2025 17:41:59

SCALD REPORT

Last Available

units:gal, in, °F

TANKS

UNLEADED
UNLEADED
Capacity: 11,608.0

Begin End
05/11/2025 05/24/2025
04:21:24 09:30:21

Result Pass

Slope 0.00

Status 99

Volume Qualify % >= 14

PREMIUM
PREMIUM
Capacity: 3,765.0

Begin End
05/25/2025 05/25/2025
15:25:24 16:51:32

Result Pass

Slope -0.06

Status 0

Volume Qualify % >= 14

DIESEL
DIESEL
Capacity: 6,044.0

Begin End
05/25/2025 05/25/2025
15:09:06 16:59:13

Result Pass

Slope 0.02

Status 0

Volume Qualify % >= 14

KEROSENE
KEROSENE
Capacity: 3,765.0

Begin End
06/20/2021 06/20/2021
18:16:32 19:42:48

Result Pass

Slope 0.00

Status 0

Volume Qualify % >= 14

JIMTOWN MOBIL
JIMTOWN MOBIL
29096 CR 20
ELKHART, IN 46517
USA
05/25/2025 17:42:05

LINE LEAK REPORT
Last Available

GROSS TEST

UNLEADED
Gross Leak Test Passed
05/25/2025 17:37:17

PREMIUM
Gross Leak Test Passed
05/25/2025 16:58:25

DIESEL
Gross Leak Test Passed
05/25/2025 17:36:33

.....

JIMTOWN MOBIL
JIMTOWN MOBIL
29096 CR 20
ELKHART, IN 46517
USA
05/25/2025 17:42:11

SENSOR REPORT
Last Available

2 WIRE SENSOR

UNLEADED STP SUMP
Alarm
05/25/2025 17:42:11

PREMIUM STP SUMP
Ok
05/25/2025 17:42:11

DIESEL STP SUMP
Alarm
05/25/2025 17:42:11

KERO STP SUMP SENSOR
Ok
05/25/2025 17:42:11

3 WIRE SENSOR

INTERSTITIAL RUL/PNL
Ok
05/25/2025 17:42:11

INTERSTITIAL DSL/KERO
Ok
05/25/2025 17:42:11

MAG SENSOR

No Records Found

JIMTOWN MOBIL
JIMTOWN MOBIL
29096 CR 20
ELKHART, IN 46517
USA
05/25/2025 17:42:17

REGULATORY REPORT
(Passed Tests)
May 2025

units:gph

TANKS (MONTHLY)

Tank 1
UNLEADED
SCALD
Slope 0.00
▶ 05/11/2025 04:21:24
▶ 05/24/2025 09:30:21
Volume Qualify % >= 14
Slope 0.01
▶ 05/03/2025 23:56:02
▶ 05/16/2025 02:06:24
Volume Qualify % >= 14

Tank 2
PREMIUM
SCALD
Slope -0.06
▶ 05/25/2025 15:25:24
▶ 05/25/2025 16:51:32
Volume Qualify % >= 14
Slope -0.01
▶ 05/11/2025 07:53:27
▶ 05/11/2025 09:19:52
Volume Qualify % >= 14

Tank 3
DIESEL
SCALD
Slope 0.02
▶ 05/25/2025 15:09:06
▶ 05/25/2025 16:59:13
Volume Qualify % >= 14
Slope 0.02
▶ 05/08/2025 06:25:37
▶ 05/08/2025 08:01:11
Volume Qualify % >= 14

LINES (MONTHLY)

Line 1
UNLEADED
Normal
05/25/2025 07:34:45
05/17/2025 03:56:03

Line 2
PREMIUM
Normal
05/25/2025 14:34:33
05/05/2025 06:09:19

Line 3
DIESEL
Normal
05/25/2025 00:35:31
05/10/2025 23:25:31

LINES (ANNUAL)

Line 1
UNLEADED
05/18/2025 08:05:37

Line 2
PREMIUM
05/22/2025 05:15:29

Line 3
DIESEL
05/22/2025 04:51:13

2 WIRE SENSOR (MONTHLY)

PREMIUM STP SUMP
05/25/2025 12:00:00
05/06/2025 12:00:00

KERO STP SUMP SENSOR
05/25/2025 12:00:00
05/21/2025 12:00:00

3 WIRE SENSOR (MONTHLY)

INTERSTITIAL RUL/PNL
05/25/2025 12:00:00
05/20/2025 12:00:00

INTERSTITIAL DSL/KERO
05/25/2025 12:00:00
05/21/2025 12:00:00

.....