

JIMTOWN MOBIL
JIMTOWN MOBIL
29096 CR 20
ELKHART, IN 46517
USA
06/26/2025 19:42:05

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

UNLEADED
UNLEADED
Capacity: 11,608.0
Begin End
06/11/2025 06/26/2025
06:17:17 06:44:20
Result Pass
Slope 0.02
Status 99
Volume Qualify % >= 14

PREMIUM
PREMIUM
Capacity: 3,765.0
Begin End
06/26/2025 06/26/2025
13:49:42 17:05:47
Result Pass
Slope -0.06
Status 0
Volume Qualify % >= 14

DIESEL
DIESEL
Capacity: 6,044.0
Begin End
06/26/2025 06/26/2025
07:26:33 09:30:47
Result Pass
Slope 0.04
Status 0
Volume Qualify % >= 14

KEROSENE
KEROSENE
Capacity: 3,765.0
Begin End
06/20/2021 06/20/2021
18:16:32 19:42:48
Result Pass
Slope 0.00
Status 0
Volume Qualify % >= 14

JIMTOWN MOBIL
JIMTOWN MOBIL
29096 CR 20
ELKHART, IN 46517
USA
06/26/2025 19:42:11

REGULATORY REPORT
(Passed Tests)
June 2025

units:gph

TANKS (MONTHLY)

Tank 1
UNLEADED
SCALD
Slope 0.02
▶ 06/11/2025 06:17:17
▶ 06/26/2025 06:44:20
Volume Qualify % >= 14
Slope 0.03
▶ 05/31/2025 02:29:39
▶ 06/12/2025 03:32:05
Volume Qualify % >= 14

Tank 2
PREMIUM
SCALD
Slope -0.06
▶ 06/26/2025 13:49:42
▶ 06/26/2025 17:05:47
Volume Qualify % >= 14
Slope 0.01
▶ 06/10/2025 05:59:03
▶ 06/10/2025 07:25:45
Volume Qualify % >= 14

Tank 3
DIESEL
SCALD
Slope 0.04
▶ 06/26/2025 07:26:33
▶ 06/26/2025 09:30:47
Volume Qualify % >= 14
Slope -0.00
▶ 06/07/2025 06:21:29
▶ 06/07/2025 07:47:46
Volume Qualify % >= 14

LINES (MONTHLY)

Line 1
UNLEADED
Normal
06/26/2025 04:56:31
06/15/2025 07:14:47

TANKS (MONTHLY)

Tank 1
UNLEADED
SCALD
Slope 0.02
▶ 06/11/2025 06:17:17
▶ 06/26/2025 06:44:20
Volume Qualify % >= 14
Slope 0.03
▶ 05/31/2025 02:29:39
▶ 06/12/2025 03:32:05
Volume Qualify % >= 14

Tank 2
PREMIUM
SCALD
Slope -0.06
▶ 06/26/2025 13:49:42
▶ 06/26/2025 17:05:47
Volume Qualify % >= 14
Slope 0.01
▶ 06/10/2025 05:59:03
▶ 06/10/2025 07:25:45
Volume Qualify % >= 14

Tank 3
DIESEL
SCALD
Slope 0.04
▶ 06/26/2025 07:26:33
▶ 06/26/2025 09:30:47
Volume Qualify % >= 14
Slope -0.00
▶ 06/07/2025 06:21:29
▶ 06/07/2025 07:47:46
Volume Qualify % >= 14

LINE (MONTHLY)

Line 1
UNLEADED
Normal
06/26/2025 04:56:31
06/15/2025 07:14:47

Line 2
PREMIUM
Normal
06/26/2025 02:11:11
06/04/2025 02:08:29

Line 3
DIESEL
Normal
06/25/2025 14:07:23
06/09/2025 22:45:13

LINE (ANNUAL)

Line 1
UNLEADED
06/26/2025 04:56:31

Line 2
PREMIUM
06/20/2025 04:39:07

Line 3
DIESEL
06/21/2025 00:29:31

2 WIRE SENSOR (MONTHLY)

PREMIUM STP SUMP
06/26/2025 12:00:00
06/04/2025 12:00:00

KERO STP SUMP SENSOR
06/26/2025 12:00:00
06/19/2025 12:00:00

3 WIRE SENSOR (MONTHLY)

INTERSTITIAL RUL/PNL
06/26/2025 12:00:00
06/18/2025 12:00:00

INTERSTITIAL DSL/KERO
06/26/2025 12:00:00
06/19/2025 12:00:00