



## CATHODIC PROTECTION

TEST DATE: 8/30/2023  
LOCATION NAME: Marycrest Marathon  
LOCATION ADDRESS: 2322 West Western Avenue  
LOCATION CITY/STATE: South Bend, IN 46619  
LOCATION PHONE: 0  
LOCATION CONTACT: Virendar Kumar

OWNER NAME: Tanks Data  
OWNER ADDRESS: 2322 West Western Avenue  
OWNER CITY/STATE/ZIP: South Bend, IN 46619  
LOCATION FID#: 10551  
WORK ORDER NO: NE-0561

SYSTEM TYPE: GALVANIC  
TEMPERATURE: 75F  
CONDITIONS: DRY  
TIME: 2:00PM

| TANK NO                 | 1     | 2     | 3     | 4  | 5 | 6 |
|-------------------------|-------|-------|-------|----|---|---|
| PRODUCT STORED          | PREM  | RUL1  | RUL2  |    |   |   |
| TANK CONTACT            | TM    | TM    | TM    |    |   |   |
| REFERENCE CELL LOCATION | LOCAL |       |       |    |   |   |
| VOLTAGE READING         | -1351 | -1126 | -1263 |    |   |   |
| REFERENCE CELL LOCATION | LOCAL | STP   | STP   | R2 |   |   |
| VOLTAGE READING         | -1150 | -1030 | -1096 |    |   |   |
| REMOTE VOLTAGE          | -867  | -852  | -963  |    |   |   |
| RESULT                  | PASS  | PASS  | PASS  |    |   |   |

JOHN LANNOM  
CERTIFIED TECHNICIAN NAME (printed)

  
CERTIFIED TECHNICIAN SIGNATURE

CERT NO: UC20129333  
EXPIRATION DATE: 8/17/2024

| LEGEND |                               |
|--------|-------------------------------|
| TW     | TEST WIRE                     |
| TB     | TANK BOTTOM                   |
| TM     | TANK MONITORING PROBE OPENING |
| INT    | INTERSTITIAL OPENING          |

### SITE DIAGRAM

