

000
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 10551

Contact Number

Facility Name MARRACON

Contact email

Address 2322 W Western Ave South Bend

Date of Inspection 05/05/24

Operator on Duty Name IN 466A

Name of the Person Conducting Inspection WATN IT SHARRAN

Operator Training current

Operator Training
☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form
☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No

Release Detection Method

Release Detection
☒ ATG ☐ DIM ☐ SIR ☐ IC ☐ Other

Make and Model

VR TCS 350

Does it have paper?

☒ Yes ☐ No
Operator Notified ☐ Yes ☐ No

Is it in Alarm mode?

☒ Yes ☐ No
Operator Notified ☐ Yes ☐ No

Interstitial Monitoring Sensor Status Normal

☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No

Necessary Monthly Printout Taken

☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No

Spill Buckets

Are Spill Buckets Clean and free from water, debris, product etc?

☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No

Are the Spill Bucket in good condition and free of damage/cracks

☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No

Fill Ports

Is Fill pipe cap tight and fill pipe free from any obstruction?

☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No

Piping/STP Sumps

Are Sumps Clean and free from water, debris, product etc?

☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No

Under Dispenser Containments (UDC)

Are UDCs clean and free from water, debris, product etc?

☐ Yes ☐ No
Operator Notified ☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tankdata@gmail.com

www.tankdata.com