

30 DAYS WALK THROUGH INSPECTION

001
Tank Data

UST Facility I.D. (FID) # 10551 Contact Number

Facility Name MARTINOV Contact email

Address 2322 W Western Ave, South Date of Inspection 07/05/24

Operator on Duty Name Brenda, MW 46619 Name of the Person Conducting Inspection AKSHIT SANAAN

Operator Training current

Operator Training
☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form
☐ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Release Detection Method

Release Detection
☒ ATG ☐ CIM

Operator Notified ☐ Yes ☐ No
☐ SIR ☐ IC ☐ Other

Make and Model

LR TL53050

Does it have paper?

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Is it in Alarm mode?

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Interstitial Monitoring Sensor Status Normal

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Necessary Monthly Printout Taken

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Spill Buckets

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Are Spill Buckets Clean and free from water, debris, product etc?

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

Fill Ports
☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Are Sumps Clean and free from water, debris, product etc?

Piping/STP Sumps
☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Are UDCs clean and free from water, debris, product etc?

Under Dispenser Containments (UDC)
☐ Yes ☒ No

Operator Notified ☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

317-645-0215

tankdata@gmail.com

Signature

Date

www.tankdata.com

20220516