



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date

10/7/24

LEAK DETECTOR TEST (DATA SHEET)

Test Location Information

Name	FID 10551
Address	2322 W Western Ave
City	South Bend
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Red Jacket ELLD		
Prem	Red Jacket ELLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular				189ml	1 cycle	Pass 
2	Premium				189ml	1 cycle	Pass 
3					189ml	.	
4					189ml	.	
5					189ml	.	
6					189ml	.	
7					189ml	.	
8					189ml	.	

Comment:

Technician Signature :

