

MARYCREST MARATHON
2322 WESTERN AVE.
SOUTH BEND IN. 46613
574 233 8375

JUN 27, 2025 5:05 PM

WPLLD LINE LEAK
TEST RESULTS

W 1:UNLEADED

3.0 GAL/HR RESULTS:

LAST TEST:
JUN 27, 2025 5:04PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 144
SINCE MIDNIGHT : 103

0.20 GAL/HR RESULTS:

JUN	2, 2025	5:18AM	PASS
MAY	1, 2025	11:40PM	PASS
APR	11, 2025	2:11AM	PASS
APR	1, 2025	4:39AM	PASS
MAR	2, 2025	7:31AM	PASS
FEB	2, 2025	6:06AM	PASS
JAN	3, 2025	1:50AM	PASS
DEC	4, 2024	2:11AM	PASS
NOV	4, 2024	2:19AM	PASS
OCT	9, 2024	10:51PM	PASS

0.10 GAL/HR RESULTS:

APR	13, 2025	3:38AM	PASS
OCT	10, 2024	12:37AM	PASS
APR	7, 2024	1:07AM	PASS
OCT	4, 2023	12:40AM	PASS
MAR	26, 2023	2:19AM	PASS
SEP	21, 2022	12:54AM	PASS
MAR	19, 2022	12:29AM	PASS
SEP	14, 2021	12:25AM	PASS
MAR	9, 2021	11:32PM	PASS
SEP	6, 2020	1:46AM	PASS

W 3:PREM

3.0 GAL/HR RESULTS:

LAST TEST:
JUN 27, 2025 5:03PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 161
SINCE MIDNIGHT : 117

0.20 GAL/HR RESULTS:

JUN	2, 2025	3:56AM	PASS
MAY	1, 2025	1:56PM	PASS
APR	1, 2025	4:38AM	PASS
MAR	2, 2025	3:33AM	PASS
FEB	2, 2025	5:52AM	PASS
JAN	31, 2025	2:08AM	PASS
JAN	29, 2025	5:42AM	PASS
JAN	1, 2025	12:31PM	PASS
DEC	2, 2024	6:09AM	PASS
NOV	2, 2024	6:41AM	PASS

0.10 GAL/HR RESULTS:

JAN	31, 2025	3:12AM	PASS
JUL	30, 2024	1:41AM	PASS
JAN	27, 2024	2:24AM	PASS
JUL	26, 2023	12:38AM	PASS
JAN	19, 2023	12:45AM	PASS
JUL	16, 2022	2:04AM	PASS
JAN	13, 2022	2:01AM	PASS
JUL	13, 2021	5:54AM	PASS
JAN	10, 2021	2:12AM	PASS
JUL	7, 2020	12:59AM	PASS

* * * * * END * * * * *

MARYCREST MARATHON
2322 WESTERN AVE.
SOUTH BEND IN. 46613
574 233 8375

JUN 27, 2025 5:05 PM

LEAK TEST REPORT

T 1:UNLEADED 1
PROBE SERIAL NUM 237692

TEST STARTING TIME:
JUN 27, 2025 1:00 AM

HEIGHT = 45.6 INCHES
WATER = 0.0 INCHES
TEMP = 71.4 F

TEST LENGTH = 2.0 HRS

W 3:PREM

3.0 GAL-HR RESULTS:

LAST TEST:
JUN 27, 2025 5:03PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 161
SINCE MIDNIGHT : 117

0.20 GAL-HR RESULTS:

JUN	2, 2025	3:56AM	PASS
MAY	1, 2025	1:56PM	PASS
APR	1, 2025	4:38AM	PASS
MAR	2, 2025	3:33AM	PASS
FEB	2, 2025	5:52AM	PASS
JAN	31, 2025	2:08AM	PASS
JAN	29, 2025	5:42AM	PASS
JAN	1, 2025	12:31PM	PASS
DEC	2, 2024	6:09AM	PASS
NOV	2, 2024	6:41AM	PASS

0.10 GAL-HR RESULTS:

JAN	31, 2025	3:12AM	PASS
JUL	30, 2024	1:41AM	PASS
JAN	27, 2024	2:24AM	PASS
JUL	26, 2023	12:38AM	PASS
JAN	19, 2023	12:45AM	PASS
JUL	16, 2022	2:04AM	PASS
JAN	13, 2022	2:01AM	PASS
JUL	13, 2021	5:54AM	PASS
JAN	10, 2021	2:12AM	PASS
JUL	7, 2020	12:59AM	PASS

***** END *****

MARYCREST MARATHON
2322 WESTERN AVE.
SOUTH BEND IN. 46613
574 233 8375

JUN 27, 2025 5:05 PM

LEAK TEST REPORT

T 1:UNLEADED 1
PROBE SERIAL NUM 237692

TEST STARTING TIME:
JUN 27, 2025 1:00 AM

HEIGHT = 45.6 INCHES
WATER = 0.0 INCHES
TEMP = 71.4 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 5528.7 GAL
PERCENT VOLUME = 46.4

LEAK TEST RESULTS
RATE = 0.09 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****

MARYCREST MARATHON
2322 WESTERN AVE.
SOUTH BEND IN. 46613
574 233 8375

JUN 27, 2025 5:05 PM

LEAK TEST REPORT

T 2:UNLEADED 2
PROBE SERIAL NUM 514015

TEST STARTING TIME:
JUN 27, 2025 1:00 AM

HEIGHT = 44.3 INCHES
WATER = 0.0 INCHES
TEMP = 72.9 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 5314.4 GAL
PERCENT VOLUME = 44.6

LEAK TEST RESULTS
RATE = -1.43 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

***** END *****

MARYCREST MARATHON
2322 WESTERN AVE.
SOUTH BEND IN. 46613
574 233 8375

JUN 27, 2025 5:05 PM

LEAK TEST REPORT

T 3:PREMIUM
PROBE SERIAL NUM 073336

TEST STARTING TIME:
JAN 15, 2024 1:00 AM

HEIGHT = 30.1 INCHES
WATER = 0.0 INCHES
TEMP = 50.4 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3209.4 GAL
PERCENT VOLUME = 27.0

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
20 GAL/HR TEST PASS

***** END *****