

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 10551		Contact Number
Facility Name Morathon	Contact email	
Address 2329 W Webster Ave South bend	Date of Inspection 04-26-25	
Operator on Duty Name JN-46619	Name of the Person Conducting Inspection Makar Singh	

Operator Training current	Operator Training	
☐ Yes	☐ No	Operator Notified ☐ Yes ☐ No
Registration current with correct owner, operator etc.	Registration/Notification Form	
☐ Yes	☐ No	Operator Notified ☐ Yes ☐ No
Release Detection Method	Release Detection	
Make and Model	☒ ATG	☐ CIM
Does it have paper?	☒ Yes	☐ No
Is it in Alarm mode?	☒ Yes	☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes	☐ No
Necessary Monthly Printout Taken	☒ Yes	☐ No
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes	☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes	☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes	☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes	☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes	☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name _____ Signature _____ Date _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com