

WATER TEMP * 30.0 INCHES
* 0.0 INCHES
* 72.0 F
TEST LENGTH * 3.0 HRS
STRT VOLUME * 3261.0 GAL
PERCENT VOLUME * 27.4
LEAK TEST RESULTS
0.20 GAL/HR TEST
0.20 GAL/HR FLASH!
PRODUCT LEVEL INCREASE
***** END *****

MARYCREST MARATHON
2322 WESTERN AVE.
SOUTH BEND IN. 46613
574 233 8375

SEP 25, 2025 4:47 PM
LEAK TEST REPORT

T 2: UNLEADED 2
PROBE SERIAL NUM 514015

TEST STARTING TIME:
SEP 24, 2025 1:00 AM

HEIGHT * 32.2 INCHES
WATER * 0.0 INCHES
TEMP * 72.5 F

TEST LENGTH * 3.0 HRS
STRT VOLUME * 3476.3 GAL
PERCENT VOLUME * 29.2

LEAK TEST RESULTS
RATE * -2.22 GAL/HR
THRS * -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

***** END *****

MARYCREST MARATHON
2322 WESTERN AVE.
SOUTH BEND IN. 46613
574 233 8375

SEP 25, 2025 4:47 PM
WPLLD LINE LEAK
TEST RESULTS

W 1: UNLEADED

3.0 GAL/HR RESULTS:

LAST TEST:
SEP 25, 2025 4:35PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 125
SINCE MIDNIGHT : 89

0.20 GAL/HR RESULTS:

SEP	2, 2025	1:17AM	PASS
AUG	3, 2025	1:20AM	PASS
JUL	2, 2025	1:50AM	PASS
JUN	2, 2025	5:18AM	PASS
MAY	1, 2025	11:40PM	PASS
APR	11, 2025	2:11AM	PASS
APR	1, 2025	4:39AM	PASS
MAR	2, 2025	7:31AM	PASS
FEB	2, 2025	6:06AM	PASS
JAN	3, 2025	1:50AM	PASS

0.10 GAL/HR RESULTS:

APR	13, 2025	3:38AM	PASS
OCT	10, 2024	12:37AM	PASS
APR	7, 2024	1:07AM	PASS
OCT	4, 2023	12:40AM	PASS
MAR	26, 2023	2:19AM	PASS
SEP	21, 2022	12:54AM	PASS
MAR	19, 2022	12:29AM	PASS
SEP	14, 2021	12:25AM	PASS
MAR	9, 2021	11:32PM	PASS
SEP	6, 2020	1:46AM	PASS

W 3: PREM

3.0 GAL/HR RESULTS:

LAST TEST:
SEP 25, 2025 4:35PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 142
SINCE MIDNIGHT : 103

0.20 GAL/HR RESULTS:

SEP	2, 2025	1:17AM	PASS
AUG	7, 2025	1:13AM	PASS
AUG	5, 2025	10:52PM	PASS
AUG	5, 2025	1:37AM	PASS
AUG	3, 2025	10:49PM	PASS
AUG	3, 2025	1:18AM	PASS
AUG	1, 2025	2:44AM	PASS
JUL	2, 2025	3:13AM	PASS
JUN	2, 2025	3:56AM	PASS
MAY	1, 2025	1:56PM	PASS

0.10 GAL/HR RESULTS:

W 1:UNLEADED

3.0 GAL/HR RESULTS:

LAST TEST:
SEP 25,2025 4:35PM PASS
NUMBER OF TESTS PASSED 125
PREV 24 HOURS : 89
SINCE MIDNIGHT :

0.20 GAL/HR RESULTS:

SEP	2,2025	1:17AM	PASS
AUG	3,2025	1:20AM	PASS
JUL	2,2025	1:50AM	PASS
JUN	2,2025	5:18AM	PASS
MAY	1,2025	11:40PM	PASS
APR	11,2025	2:11AM	PASS
APR	1,2025	4:39AM	PASS
MAR	2,2025	7:31AM	PASS
FEB	2,2025	6:06AM	PASS
JAN	3,2025	1:50AM	PASS

0.10 GAL/HR RESULTS:

APR	13,2025	3:38AM	PASS
OCT	10,2024	12:37AM	PASS
APR	7,2024	1:07AM	PASS
OCT	4,2023	12:40AM	PASS
MAR	26,2023	2:19AM	PASS
SEP	21,2022	12:54AM	PASS
MAR	19,2022	12:29AM	PASS
SEP	14,2021	12:25AM	PASS
MAR	9,2021	11:32PM	PASS
SEP	6,2020	1:46AM	PASS

W 3:PREM

3.0 GAL/HR RESULTS:

LAST TEST:
SEP 25,2025 4:35PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 142
SINCE MIDNIGHT : 103

0.20 GAL/HR RESULTS:

SEP	2,2025	1:17AM	PASS
AUG	7,2025	1:13AM	PASS
AUG	5,2025	10:52PM	PASS
AUG	5,2025	1:37AM	PASS
AUG	3,2025	10:49PM	PASS
AUG	3,2025	1:18AM	PASS
AUG	1,2025	2:44AM	PASS
JUL	2,2025	3:13AM	PASS
JUN	2,2025	3:56AM	PASS
MAY	1,2025	1:56PM	PASS

0.10 GAL/HR RESULTS:

AUG	7,2025	2:48AM	PASS
JAN	31,2025	3:12AM	PASS
JUL	30,2024	1:41AM	PASS
JAN	27,2024	2:24AM	PASS
JUL	26,2023	12:38AM	PASS
JAN	19,2023	12:45AM	PASS
JUL	16,2022	2:04AM	PASS
JAN	13,2022	2:01AM	PASS
JUL	13,2021	5:54AM	PASS
JAN	10,2021	2:12AM	PASS

***** END *****

MARYCREST MARATHON
2322 WESTERN AVE.
SOUTH BEND IN.46613
574 233 8375

SEP 25, 2025 4:47 PM

LEAK TEST REPORT

T 3:PREMIUM
PROBE SERIAL NUM 073336

TEST STARTING TIME:
JAN 15, 2024 1:00 AM

HEIGHT = 30.1 INCHES
WATER = 0.0 INCHES
TEMP = 50.4 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3209.4 GAL
PERCENT VOLUME = 27.0

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****