

MARYCREST MARATHON
2322 WESTERN AVE.
SOUTH BEND IN. 46613
574 233 8375

MAY 30, 2025 3:50 PM

LEAK TEST REPORT

T 1: UNLEADED 1
PROBE SERIAL NUM 237692

TEST STARTING TIME:
MAY 26, 2025 1:00 AM
HEIGHT = 30.9 INCHES
WATER = 0.0 INCHES
TEMP = 60.1 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3315.4 GAL
PERCENT VOLUME = 27.8

LEAK TEST RESULTS
RATE = 0.05 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****

MARYCREST MARATHON
2322 WESTERN AVE.
SOUTH BEND IN. 46613
574 233 8375

MAY 30, 2025 3:50 PM

LEAK TEST REPORT

T 2: UNLEADED 2
PROBE SERIAL NUM 514015

TEST STARTING TIME:
MAY 25, 2025 1:00 AM
HEIGHT = 33.7 INCHES
WATER = 0.0 INCHES
TEMP = 61.2 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 3721.9 GAL
PERCENT VOLUME = 31.3

LEAK TEST RESULTS
RATE = -6.40 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

***** END *****

MARYCREST MARATHON
2322 WESTERN AVE.
SOUTH BEND IN. 46613
574 233 8375

MAY 30, 2025 3:50 PM

WPLD LINE LEAK
TEST RESULTS

W 1: UNLEADED

3.0 GAL/HR RESULTS:

LAST TEST:
MAY 30, 2025 3:49PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 150

SINCE MIDNIGHT : 89

0.20 GAL/HR RESULTS:

MAY 1, 2025 11:40PM PASS

APR 11, 2025 2:11AM PASS

APR 1, 2025 4:39AM PASS

MAR 2, 2025 7:31AM PASS

FEB 2, 2025 6:06AM PASS

JAN 3, 2025 1:50AM PASS

DEC 4, 2024 2:11AM PASS

NOV 4, 2024 2:19AM PASS

OCT 9, 2024 10:51PM PASS

OCT 7, 2024 11:59PM PASS

0.10 GAL/HR RESULTS:

APR 13, 2025 3:38AM PASS

OCT 10, 2024 12:37AM PASS

APR 7, 2024 1:07AM PASS

OCT 4, 2023 12:40AM PASS

MAR 26, 2023 2:19AM PASS

SEP 21, 2022 12:54AM PASS

MAR 19, 2022 12:29AM PASS

SEP 14, 2021 12:25AM PASS

MAR 9, 2021 11:32PM PASS

SEP 6, 2020 1:46AM PASS

W 3: PREM

3.0 GAL/HR RESULTS:

LAST TEST:
MAY 30, 2025 3:50PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 167

SINCE MIDNIGHT : 96

0.20 GAL/HR RESULTS:

MAY 1, 2025 1:56PM PASS

APR 1, 2025 4:38AM PASS

MAR 2, 2025 3:33AM PASS

FEB 2, 2025 5:52AM PASS

JAN 31, 2025 2:08AM PASS

JAN 29, 2025 5:42AM PASS

JAN 1, 2025 12:31PM PASS

DEC 2, 2024 6:09AM PASS

NOV 2, 2024 6:41AM PASS

OCT 1, 2024 11:55PM PASS

0.10 GAL/HR RESULTS:

JAN 31, 2025 3:12AM PASS

JUL 30, 2024 1:41AM PASS

JAN 27, 2024 2:24AM PASS

JUL 26, 2023 12:38AM PASS

JAN 19, 2023 12:45AM PASS

JUL 16, 2022 2:04AM PASS

JAN 13, 2022 2:01AM PASS

JUL 13, 2021 5:54AM PASS

JAN 10, 2021 2:12AM PASS

JUL 7, 2020 12:59AM PASS

* * * * * END * * * * *

MARYCREST MARATHON
2322 WESTERN AVE.
SOUTH BEND IN. 46613
574 233 8375

MAY 30, 2025 3:50 PM

LEAK TEST REPORT

T 3:PREMIMUM
PROBE SERIAL NUM 073336

TEST STARTING TIME:
JAN 15, 2024 1:00 AM

HEIGHT	=	30.1 INCHES
WATER	=	0.0 INCHES
TEMP	=	50.4 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3209.4 GAL
PERCENT VOLUME = 27.0

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *