

30 DAYS WALK THROUGH INSPECTION

Tanks Data

UST Facility I.D. (FID) # 10551

Facility Name MARATHON

Address 2322 Western Ave, South

Operator on Duty Name Bend, NY 6619

Contact Number

Contact email

Date of Inspection 01/24/25

Name of the Person Conducting Inspection AKSHIT

Operator Training current

Operator Training ☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form ☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Release Detection Method

Release Detection ☒ ATG ☐ EIM ☐ BIR ☐ IC ☐ Other

Make and Model

VR TL5350

Does it have paper?

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Is it in Alarm mode?

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Interstitial Monitoring Sensor Status Normal

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Necessary Monthly Printout Taken

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Spill Buckets

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Are Spill Buckets Clean and free from water, debris, product etc?

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Fill Ports

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Pipeline/STP Sumps

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Are Sumps Clean and free from water, debris, product etc?

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Under Dispenser Containments (UDC)

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Are UDCs clean and free from water, debris, product etc?

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com