

***** END *****

MARYCREST MARATHON
2322 WESTERN AVE.
SOUTH BEND IN.46613
574 233 8375

AUG 26, 2025 5:53 PM

LEAK TEST REPORT

T 1:UNLEADED 1
PROBE SERIAL NUM 237692

TEST STARTING TIME:
AUG 24, 2025 1:00 AM

HEIGHT = 33.3 INCHES
WATER = 0.0 INCHES
TEMP = 76.2 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 3625.5 GAL
PERCENT VOLUME = 30.4

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
PRODUCT LEVEL INCREASE

***** END *****

MARYCREST MARATHON
2322 WESTERN AVE.
SOUTH BEND IN.46613
574 233 8375

AUG 26, 2025 5:53 PM

LEAK TEST REPORT

T 2:UNLEADED 2
PROBE SERIAL NUM 514015

TEST STARTING TIME:
AUG 24, 2025 1:00 AM

HEIGHT = 32.1 INCHES
WATER = 0.0 INCHES
TEMP = 77.6 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 3442.9 GAL
PERCENT VOLUME = 28.9

LEAK TEST RESULTS
RATE = -1.62 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

***** END *****

MARYCREST MARATHON
2322 WESTERN AVE.
SOUTH BEND IN.46613
574 233 8375

AUG 26, 2025 5:53 PM

LEAK TEST REPORT

T 3:PREMIUM
PROBE SERIAL NUM 073336

TEST STARTING TIME:
JAN 15, 2024 1:00 AM

HEIGHT = 30.1 INCHES
WATER = 0.0 INCHES
TEMP = 50.4 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3209.4 GAL
PERCENT VOLUME = 27.0

LEAK TEST RESULTS
0.00 GAL/HR