

MARYCREST MARATHON
2322 WESTERN AVE.
SOUTH BEND IN. 46613
574 233 8375
APR 26, 2025 3:08 PM
T 1:UNLEADED
PROBE SERIAL NUM 237692
TEST STARTING TIME:
APR 22, 2025 1:00 AM
HEIGHT = 32.8 INCHES
WATER = 0.8 INCHES
TEMP = 91.7 F
TEST LENGTH = 3.0 HRS
STRT VOLUME = 1609.3 GAL
PERCENT VOLUME = 30.3
LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

END *****

MARYCREST MARATHON
2322 WESTERN AVE.
SOUTH BEND IN. 46613
574 233 8375
APR 26, 2025 3:08 PM
T 2:UNLEADED
PROBE SERIAL NUM 514015
TEST STARTING TIME:
APR 22, 2025 1:00 AM
HEIGHT = 31.8 INCHES
WATER = 0.0 INCHES
TEMP = 99.8 F
TEST LENGTH = 2.0 HRS
STRT VOLUME = 3456.1 GAL
PERCENT VOLUME = 29.0
LEAK TEST RESULTS
RATE = -0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

END *****

MARYCREST MARATHON
2322 WESTERN AVE.
SOUTH BEND IN. 46613
574 233 8375
APR 26, 2025 3:08 PM
WPLD LINE LEAK
TEST RESULTS
W 1:UNLEADED
3.0 GAL/HR RESULTS:
LAST TEST:
APR 26, 2025 3:00PM PASS
NUMBER OF TESTS PASSED : 116
PREV 24 HOURS : 63
SINCE MIDNIGHT : 63

0.20 GAL/HR RESULTS:
APR 11, 2025 2:11AM PASS
MAR 1, 2025 4:39AM PASS
FEB 2, 2025 7:31AM PASS
JAN 2, 2025 6:06AM PASS
DEC 3, 2025 1:50AM PASS
NOV 4, 2024 2:11AM PASS
OCT 9, 2024 2:19AM PASS
OCT 7, 2024 10:51PM PASS
OCT 1, 2024 11:59PM PASS
OCT 1, 2024 11:56PM PASS

0.10 GAL/HR RESULTS:
APR 13, 2025 3:38AM PASS
OCT 10, 2024 12:37AM PASS
APR 7, 2024 1:07AM PASS
MAR 4, 2023 12:40AM PASS
SEP 26, 2023 2:19AM PASS
MAR 21, 2022 12:54AM PASS
SEP 19, 2022 12:29AM PASS
MAR 14, 2021 12:25AM PASS
SEP 9, 2021 11:32PM PASS
SEP 6, 2020 1:46AM PASS

W 3:PREM
3.0 GAL/HR RESULTS:
LAST TEST:
APR 26, 2025 3:00PM PASS
NUMBER OF TESTS PASSED : 115
PREV 24 HOURS : 59
SINCE MIDNIGHT : 59

0.20 GAL/HR RESULTS:
APR 1, 2025 4:38AM PASS
MAR 2, 2025 3:33AM PASS
FEB 2, 2025 5:52AM PASS
JAN 31, 2025 2:08AM PASS
JAN 29, 2025 5:42AM PASS
JAN 1, 2025 12:31PM PASS
DEC 2, 2024 6:09AM PASS
NOV 2, 2024 6:41AM PASS
OCT 1, 2024 11:55PM PASS
SEP 3, 2024 6:00AM PASS

0.10 GAL/HR RESULTS:
JAN 31, 2025 3:12AM PASS
JUL 30, 2024 1:41AM PASS
JAN 27, 2024 2:24AM PASS
JUL 26, 2023 12:38AM PASS
JAN 19, 2023 12:45AM PASS
JUL 16, 2022 2:04AM PASS
JAN 13, 2022 2:01AM PASS
JUL 13, 2021 5:54AM PASS
JAN 10, 2021 2:12AM PASS
JUL 7, 2020 12:59AM PASS

***** END *****

MARYCREST MARATHON
2322 WESTERN AVE.
SOUTH BEND IN. 46613
574 233 8375
APR 26, 2025 3:08 PM
LEAK TEST REPORT
T 3:PREMIUM
PROBE SERIAL NUM 073336
TEST STARTING TIME:
JAN 15, 2024 1:00 AM
HEIGHT = 30.1 INCHES
WATER = 0.0 INCHES
TEMP = 50.4 F
TEST LENGTH = 2.0 HRS
STRT VOLUME = 3209.4 GAL
PERCENT VOLUME = 27.0
LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

END *****