

60-Day Inspection Results for Impressed Current Cathodic Protection Systems

FACILITY NAME: SR 23 Expo Empire

AMP RANGE RECOMMENDED: _____

VOLTAGE RANGE RECOMMENDED: _____

Date	Your Name	Voltage Reading	Amp Reading	Is Your System Running Properly? (Yes/No)
10-16-2024	Jagjit Singh	60	2.8	Yes
10-17-2024	Jagjit Singh	60	2.8	Yes
10-18-2024	Jagjit Singh	60	2.8	Yes
10-19-2024	Jagjit Singh	60	2.8	Yes
10-20-24	Jagjit Singh	60	2.7	Yes
10-20-24	Jagjit Singh	60	2.7	Yes
10-21-24	Jagjit Singh	60	2.7	Yes
10-22-24	Jagjit Singh	60	2.7	Yes
10-23-24	Jagjit Singh	60	2.7	Yes
10-24-24	Jagjit Singh	60	2.7	Yes
10-25-24	Jagjit Singh	60	2.7	Yes
10-26-24	Jagjit Singh	60	2.7	Yes
10-27-24	Jagjit Singh	60	2.7	Yes
10-28-24	Jagjit Singh	61	2.8	Yes
10-29-24	Jagjit Singh	61	2.8	Yes
10-30-24	Jagjit Singh	61	2.8	Yes
10-31-24	Jagjit Singh	61	2.8	Yes

- If the rectifier voltage and/or amperage output(s) are outside the recommended operating levels, contact a cathodic protection expert to address the problem.
- Never turn off your rectifier.
- KEEP THIS RECORD FOR AT LEAST 6 MONTHS AFTER THE DATE OF THE LAST READING

60-Day Inspection Results for Impressed Current Cathodic Protection Systems

FACILITY NAME: SN Expo Empire

AMP RANGE RECOMMENDED: _____

VOLTAGE RANGE RECOMMENDED: _____

Date	Your Name	Voltage Reading	Amp Reading	Is Your System Running Properly? (Yes/No)
11/1-24	Jagjit Singh	61	2.8	Yes
11/2-24	Jagjit Singh	61	2.8	Yes
11/3-24	Jagjit Singh	61	2.8	Yes
11/4-24	Jagjit Singh	61	2.8	Yes
11/5-24	Jagjit Singh	61	2.8	Yes
11/6-24	RAMAN	61	2.8	Yes
11-7-24	RAMAN	61	2.7	Yes
11-8-24	RAMAN	62	2.7	Yes
11-9-24	RAMAN	62	2.7	Yes
11-10-24	RAMAN	62	2.7	Yes
11-11-24	RAMAN	62	2.7	Yes
11-12-24	RAMAN	62	2.8	Yes
11-13-24	RAMAN	62	2.8	Yes
11-14-24	RAMAN	62	2.6	Yes
11-15-24	RAMAN	62	2.6	Yes
11-16-24	RAMAN	62	2.7	Yes
11-17-24	RAMAN	62	2.7	Yes
11-18-24	RAMAN	62	2.7	Yes

- If the rectifier voltage and/or amperage output(s) are outside the recommended operating levels, contact a cathodic protection expert to address the problem.
- Never turn off your rectifier.
- KEEP THIS RECORD FOR AT LEAST 6 MONTHS AFTER THE DATE OF THE LAST READING

60-Day Inspection Results for Impressed Current Cathodic Protection Systems

FACILITY NAME: SR 22 GPS Engine

AMP RANGE RECOMMENDED: _____

VOLTAGE RANGE RECOMMENDED: _____

Date	Your Name	Voltage Reading	Amp Reading	Is Your System Running Properly? (Yes/No)
11-19-24	Teresa R	62	2.7	Yes
11-20-24	Teresa R	62	2.7	Yes
11-21-24	Teresa R.	62	2.7	Yes
11-22-24	Teresa R	62	2.7	Yes
11-23-24	Teresa R	62	2.7	Yes
11-24-24	Teresa R.	62	2.7	Yes
11-25-24	Teresa R	62	2.7	Yes
11-26-24	Teresa R.	62	2.7	Yes
11-27-24	Teresa R.	61	2.8	Yes
11-28-24	Teresa K.	61	2.8	Yes
11-29-24	Teresa R	61	2.8	Yes
11-30-24	Teresa K	61	2.8	Yes
12-1-24	Teresa R.	61	2.8	Yes
12-2-24	Teresa R.	61	2.8	Yes
12-3-24	Teresa R.	61	2.8	Yes
12-4-24	Teresa R.	61	2.8	Yes
12-5-24	Teresa K.	61	2.8	Yes
12-6-24	Teresa R.	61	2.8	Yes

- If the rectifier voltage and/or amperage output(s) are outside the recommended operating levels, contact a cathodic protection expert to address the problem.
- Never turn off your rectifier.
- KEEP THIS RECORD FOR AT LEAST 6 MONTHS AFTER THE DATE OF THE LAST READING

60-Day Inspection Results for Impressed Current Cathodic Protection Systems

FACILITY NAME: SR 22 Exp. Empire

AMP RANGE RECOMMENDED: _____

VOLTAGE RANGE RECOMMENDED: _____

Date	Your Name	Voltage Reading	Amp Reading	Is Your System Running Properly? (Yes/No)
12-7-24	Teresa R.	61	2.8	Yes
12-8-24	Teresa R.	61	2.8	Yes
12/9/24	Teresa R.	61	2.8	Yes
12-10-24	Teresa R.	61	2.8	Yes
12-11-24	Teresa R.	61	2.8	Yes
12-12-24	Teresa R.	61	2.8	Yes
12-13-24	JAGG	70	2.9	Yes
12-14-24	JAGG	70	2.9	Yes
12-15-24	JAGG	70	2.8	Yes
12-16-24	JAGG	70	2.8	Yes

- If the rectifier voltage and/or amperage output(s) are outside the recommended operating levels, contact a cathodic protection expert to address the problem.
- Never turn off your rectifier.
- KEEP THIS RECORD FOR AT LEAST 6 MONTHS AFTER THE DATE OF THE LAST READING