

JAN 24, 2024 3:35 PM
CSLD TEST RESULTS

JAN 24, 2024 3:35 PM

T 1:UNL
PROBE SERIAL NUM 236752
0.2 GAL/HR TEST
PER: JAN 24, 2024 PASS

T 2:FREM
PROBE SERIAL NUM 236923
0.2 GAL/HR TEST
PER: JAN 24, 2024 PASS

T 3:DIESEL
PROBE SERIAL NUM 241675
0.2 GAL/HR TEST
PER: JAN 24, 2024 PASS

***** END *****

JAN 24, 2024 3:36 PM
LIQUID STATUS

JAN 24, 2024 3:36 PM

L 1:87
SENSOR NORMAL

L 2:UNL INT
FUEL ALARM

L 3:SPLIT INT
FUEL ALARM

L 4:FREMIUM STP
FUEL ALARM

L 5:DIESEL STP
FUEL ALARM

***** END *****

JAN 24, 2024 3:36 PM
LEAK TEST REPORT
T 1:UNL
PROBE SERIAL NUM 236752

NO TEST DATA AVAILABLE
***** END *****

JAN 24, 2024 3:36 PM
LEAK TEST REPORT
T 2:FREM
PROBE SERIAL NUM 236923

NO TEST DATA AVAILABLE
***** END *****

JAN 24, 2024 3:36 PM
LEAK TEST REPORT
T 3:DIESEL
PROBE SERIAL NUM 241675

NO TEST DATA AVAILABLE
***** END *****