

MAY 5, 2024 12:57 PM

LEAK TEST REPORT

T 1:UNL
PROBE SERIAL NUM 236752

NO TEST DATA AVAILABLE

* * * * * END * * * * *

MAY 5, 2024 12:57 PM

OSLD TEST RESULTS

MAY 5, 2024 12:57 PM

T 1:UNL
PROBE SERIAL NUM 236752

0.2 GAL/HR TEST
PER: MAY 5, 2024 PASS

T 2:PREM
PROBE SERIAL NUM 236923

0.2 GAL/HR TEST
PER: MAY 5, 2024 PASS

T 3:DIESEL
PROBE SERIAL NUM 241675

0.2 GAL/HR TEST
PER: MAY 5, 2024 PASS

* * * * * END * * * * *

MAY 5, 2024 12:58 PM

LEAK TEST REPORT

T 2:PREM
PROBE SERIAL NUM 236923

NO TEST DATA AVAILABLE

***** END *****

MAY 5, 2024 12:58 PM

LIQUID STATUS

MAY 5, 2024 12:58 PM

L 1:87
SENSOR NORMAL

L 2:UNL INT
SENSOR NORMAL

L 3:SPLIT INT
FUEL ALARM

L 4:PREMIUM STP
FUEL ALARM

L 5:DIESEL STP
FUEL ALARM

***** END *****

LEAK TEST STATUS:
TEST NOT IN PROGRESS

MAY 5, 2024 12:58 PM

LEAK TEST REPORT

T 3:DIESEL
PROBE SERIAL NUM 241675

NO TEST DATA AVAILABLE

***** END *****