

JUN 3, 2024 4:57 PM

CSLD TEST RESULTS

JUN 3, 2024 4:57 PM

T 1:UNL  
PROBE SERIAL NUM 236752

0.2 GAL/HR TEST  
PER: JUN 3, 2024 PASS

T 2:PREM  
PROBE SERIAL NUM 236923

0.2 GAL/HR TEST  
PER: JUN 3, 2024 PASS

T 3:DIESEL  
PROBE SERIAL NUM 241675

0.2 GAL/HR TEST  
PER: JUN 3, 2024 PASS

\* \* \* \* \* END \* \* \* \* \*

JUN 3, 2024 4:57 PM

LIQUID STATUS

JUN 3, 2024 4:57 PM

L 1:87  
SENSOR NORMAL

L 2:UNL INT  
SENSOR NORMAL

L 3:SPLIT INT  
FUEL ALARM

L 4:PREMIUM STP  
SENSOR NORMAL

L 5:DIESEL STP  
FUEL ALARM

\* \* \* \* \* END \* \* \* \* \*

JUN 3, 2024 4:57 PM

LEAK TEST REPORT

T 1:UNL  
PROBE SERIAL NUM 236752

NO TEST DATA AVAILABLE

\* \* \* \* \* END \* \* \* \* \*

JUN 3, 2024 4:57 PM

LEAK TEST REPORT

T 2:PREM  
PROBE SERIAL NUM 236923

NO TEST DATA AVAILABLE

\* \* \* \* \* END \* \* \* \* \*

JUN 3, 2024 4:57 PM

LEAK TEST REPORT

T 3:DIESEL  
PROBE SERIAL NUM 241675

NO TEST DATA AVAILABLE

\* \* \* \* \* END \* \* \* \* \*