

JUL 5, 2024 6:05 PM

CSLD TEST RESULTS

JUL 5, 2024 6:05 PM

T 1:UNL
PROBE SERIAL NUM 236752

0.2 GAL/HR TEST
PER: JUL 5, 2024 PASS

T 2:PREM
PROBE SERIAL NUM 236923

0.2 GAL/HR TEST
PER: JUL 5, 2024 PASS

T 3:DIESEL
PROBE SERIAL NUM 241675

0.2 GAL/HR TEST
PER: JUL 5, 2024 PASS

* * * * * END * * * * *

JUL 5, 2024 6:05 PM

LIQUID STATUS

JUL 5, 2024 6:05 PM

L 1:87
SENSOR NORMAL

L 2:UNL INT
SENSOR NORMAL

L 3:SPLIT INT
FUEL ALARM

L 4:PREMIUM STP
SENSOR NORMAL

L 5:DIESEL STP
FUEL ALARM

* * * * * END * * * * *

JUL 5, 2024 6:06 PM

LEAK TEST REPORT

T 1:UNL
PROBE SERIAL NUM 236752

NO TEST DATA AVAILABLE

* * * * * END * * * * *

JUL 5, 2024 6:06 PM

LEAK TEST REPORT

T 2:PREM
PROBE SERIAL NUM 236923

NO TEST DATA AVAILABLE

* * * * * END * * * * *

JUL 5, 2024 6:06 PM

LEAK TEST REPORT

T 3:DIESEL
PROBE SERIAL NUM 241675

NO TEST DATA AVAILABLE

* * * * * END * * * * *