

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	14361	Contact Number	
Facility Name	Amoco	Contact email	
Address	59572, 10000 Avenue Rd, South Bend, IN-46614	Date of Inspection	04-26-25
Operator on Duty Name		Name of the Person Conducting Inspection	Mark Long

Operator Training current	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Registration current with correct owner, operator etc.	Registration/Notification Form		Operator Notified	☐ Yes	☐ No
Release Detection Method	Release Detection		Operator Notified	☐ Yes	☐ No
Make and Model	ATG	CIM	Operator Notified	☐ Yes	☐ No
Does it have paper?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Is it in Alarm mode?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Necessary Monthly Printout Taken	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No

Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name _____ Signature _____ Date _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com