

MAY 30, 2025 3:08 PM
LEAK TEST REPORT
T 1:UNL
PROBE SERIAL NUM 236752
NO TEST DATA AVAILABLE
***** END *****

MAY 30, 2025 3:08 PM
CSLD TEST RESULTS

MAY 30, 2025 3:08 PM

T 1:UNL
PROBE SERIAL NUM 236752
0.2 GAL/HR TEST
PER: MAY 30, 2025 PASS

T 2:PREM
PROBE SERIAL NUM 236923
0.2 GAL/HR TEST
PER: MAY 30, 2025 PASS

T 3:DIESEL
PROBE SERIAL NUM 241675
0.2 GAL/HR TEST
PER: MAY 30, 2025 PASS

***** END *****

MAY 30, 2025 3:08 PM
LIQUID STATUS

MAY 30, 2025 3:08 PM

L 1:87
SENSOR NORMAL

L 2:UNL INT
SENSOR NORMAL

L 3:SPLIT INT
SENSOR NORMAL

L 4:PREMIUM STP
SENSOR NORMAL

L 5:DIESEL STP
SENSOR NORMAL

***** END *****

MAY 30, 2025 3:08 PM
LEAK TEST REPORT

T 2:PREM
PROBE SERIAL NUM 236923

NO TEST DATA AVAILABLE
***** END *****

MAY 30, 2025 3:08 PM
LEAK TEST REPORT

T 3:DIESEL
PROBE SERIAL NUM 241675

NO TEST DATA AVAILABLE
***** END *****